




A	DIA.	LENGTH	REMARKS	NUTS	THR'D
8	7 8	8	CROSSARM STRAPS / CROSSARM.	2	2 1/2
5	7 8	7	"	2	2 1/2



PLAN

1091010563 Sht 2

BOLT : TO BS 916 THREADED BSW SUPPLIED WITH STRAP
MATERIAL :- MILD STEEL GALVANISED TO BS 729

D		drawn N.F.	HV. OVERHEAD LINES
		traced R.S-S	
C		checked JLS	CROSSARM STRAP 28,000lb f. M.F.L.
		date 25-9-70	
B		scale 1/2 FULL SIZE	
A		Yorkshire Electricity Board	Y003X2211