

Document reference		NPS/001/011					
Version:-	3	Date of Issue:-	Mar-07	Page	1	of	8

NPS/001/011 – Specification for Notice Plates and Signs

1. Purpose

This document details the requirements for all notice plates, signs and labels for use on the distribution network of CE Electric UK.

This document supersedes the following documents, all copies of which should be destroyed.

Ref	Version	Title
NPS/001/011	2.0	Specification for Notice Plates and Sign
NPS/001/011	1.0	Specification for Notice Plates and Sign for use on the NEDL and YEDL Distribution Networks
Ms-O-27		Specification for Notice Plates and Signs for Use on NEDL and YEDL Distribution Systems

2. Scope

This Specification outlines the materials, dimensions, colours and technical requirements for notice plates, signs and labels use on the distribution networks of CE Electric UK. Appendix 1 details CEEUK commodity codes, descriptions and drawing numbers.

3. Technical Requirements

3.1 General Requirements

Materials and Finish

The materials and finish of all component parts referred to in this specification shall be as required in the relevant clauses of national and international standards where applicable.

Markings

All signs, notices and labels shall be marked in an appropriate area with a manufacturer identifying mark or logo and two digits to indicate the year of manufacture.

3.2 Environmental Operating Conditions for Signs

All signs and plates shall be suitable for use in the following operating conditions:

- Temperature range -10 °C - +40°C
- Located in direct sunlight
- Mounted on creosote treated wood poles (where applicable).

Document reference		NPS/001/011					
Version:-	3	Date of Issue:-	Mar-07	Page	2	of	8

3.3 Technical Requirements

3.3.1 Safety Signs

All safety signs shall fully comply with the requirements of the Electricity Safety, Quality and Continuity Regulations 2002 and ENATS 43-90: Issue 4.

Safety Signs shall be manufactured from a suitable material to provide colour fastness for a minimum period of 10 years in direct sunlight.

3.3.2 Caution and Danger Notices

Caution and Danger Notices shall be manufactured from ABS Grade 'A' white plastic with lettering and background colouring as specified on the appropriate drawing numbers.

A range of self-adhesive and magnetic notices is also included in this range.

Pole Scarves will be manufactured from reinforced plastic material with two 500-mm long Velcro strips to each of the opposite sides to form a fastening.

3.3.3 Warning Notices

Circuit Warning Notices, Stop Think Tags, Confined Spaces and Asbestos Warning Labels shall be manufactured from ABS Grade 'A' plastic with lettering and background colours as specified on the appropriate drawings.

G78 Connection Warning Plate to be manufactured as detailed in section 3.3.1 for attachment to creosote treated wood poles.

Fishing Notices and Rail-track Markers shall be manufactured from a suitable material to provide colour fastness for a minimum period of 10 years in direct sunlight.

3.3.4 Voltage Plates

Voltage plates shall be manufactured from a suitable material to provide colour fastness for a minimum period of 10 years in direct sunlight with letters and background colour as specified on the appropriate drawing.

3.3.5 Substation Name Plates

Substation name plates shall be manufactured from a suitable material to provide colour fastness for a minimum period of 10 years in direct sunlight with letters and background colour as specified on the appropriate drawing.

3.3.6 Phase Plates

Phase plates shall be manufactured from a suitable material to provide colour fastness for a minimum period of 10 years in direct sunlight.

3.3.7 Number Plates

The pole number base plate shall be manufactured from aluminium of such thickness to allow for pole curve and finished in matt black. The preferred size is 500 x 50 mm.

Numbers and letters shown on the drawing shall be manufactured from 20mm wide aluminium at the correct height to allow a sliding fit into the base plate. Characters are 25mm high with colours as specified on the drawing. The material shall be treated to prevent ultra violet deterioration and be creosote resistant.

Labels for BT attachments to poles are manufactured from ICI Propathene 203/63/white code 005 with black heat and pressure film impregnated characters. Similar materials would be considered.

Document reference		NPS/001/011					
Version:-	3	Date of Issue:-	Mar-07	Page	3	of	8

4. References

4.1 External Documentation

Reference	Title
ENA TS 43-90 Issue 4 - 1993	Anti Climbing Devices and Safety Signs for HV Lines up to and Including 400kV
ESQC: 2002	The Electricity Safety, Quality and Continuity Regulations 2002

4.2 Internal documentation

Reference	Title
-----------	-------

5. Definitions

Term	Definition
------	------------

Document reference		NPS/001/011					
Version:-	3	Date of Issue:-	Mar-07	Page	4	of	8

6. Authority for issue

6.1 Author

I sign to confirm that I have completed and checked this document and I am satisfied with its content and submit it for approval and authorisation.

		Sign	Date
S Salkeld	Standards Engineer	S Salkeld	14/03/07

6.2 Policy Sponsor

I sign to confirm that I am satisfied with all aspects of the content and preparation of this document and submit it for approval and authorisation.

		Sign	Date
G Bolden	Purchasing Manager	G Bolden	15/03/07

6.3 Technical Assurance

I sign to confirm that I am satisfied with all aspects of the content and preparation of this document and submit it for approval and authorisation.

		Sign	Date
G Hammel	Overhead Standards Manager	G Hammel	15/03/07

6.4 DBD Assurance

I sign to confirm that this document has been assured for issue on to the DBD system

		Sign	Date
S Johnson	DBD Administrator	S Johnson	23/03/07

6.5 Approval

Approval is given for the content of this document

		Sign	Date
C Holdsworth	Standards and Assessments Manager	C Holdsworth	15/03/07

6.6 Authorisation

Authorisation is granted for publication of this document

		Sign	Date
C Morgan	Head of Procurement	C Morgan	15/03/07

Document reference		NPS/001/011					
Version:-	3	Date of Issue:-	Mar-07	Page	5	of	8

Appendix 1 – Schedule of Items

COMMODITY	DESCRIPTION	DRAWING
-----------	-------------	---------

SAFETY SIGNS

361628	S/S DOOR SAFETY SIGN	1.10.102.0007 sheet 2
361613	S/S FENCE/COMPOUND SAFETY SIGN	1.10.102.0007 sheet 1
363318	WOOD POLE SAFETY SIGN	1.09.101.0229 sheet 1
363322	MAST SAFETY SIGN	1.09.101.0229 sheet 2
363587	TOWER SAFETY SIGN	1.09.101.0229 sheet 3
360112	POLE SAFETY SIGN (SELF ADHESIVE)	1.09.101.0229 sheet 10
362541	LIVE CONDUCTORS OVERHEAD	1.10.110.0002 sheet 2

CAUTION & DANGER NOTICES

321368	DANGER NOTICE EXTRA LARGE	1.10.110.0001 sheet 1
321369	DANGER NOTICE LARGE	1.10.110.0001 sheet 1
321372	DANGER NOTICE MEDIUM	1.10.110.0001 sheet 1
321264	DANGER NOTICE SMALL	1.10.110.0001 sheet 1
321350	DANGER NOTICE MAGNETIC	1.10.110.0001 sheet 1
321349	CAUTION NOTICE LARGE	1.10.110.0003 sheet 1
321353	CAUTION NOTICE MEDIUM	1.10.110.0003 sheet 1
329980	CAUTION NOTICE SMALL	1.10.110.0003 sheet 1
329987	CAUTION NOTICE MAGNETIC	1.10.110.0003 sheet 1
362545	CONSTRUCTION EARTH MEDIUM	1.10.110.0013 sheet 1
362527	CONSTRUCTION EARTH SMALL.	1.10.110.0013 sheet 1
362551	CONSTRUCTION EARTH LARGE	1.10.110.0013 sheet 1
362546	CIRCUIT MAIN EARTH MEDIUM	1.10.110.0012 sheet 1
362528	CIRCUIT MAIN EARTH SMALL	1.10.110.0012 sheet 1
300772	DANGER/CAUTION POLE SCARF	1.10.110.0004 sheet 1
300774	PROTECTION POLE SCARF	1.10.110.0008 sheet 1

Document reference		NPS/001/011					
Version:-	3	Date of Issue:-	Mar-07	Page	6	of	8

COMMODITY	DESCRIPTION	DRAWING
-----------	-------------	---------

WARNING NOTICES

297224	CIRCUIT IN COMMISSION NOTICE MEDIUM	1.10.110.0005 sheet 1
297296	CIRCUIT IN COMMISSION NOTICE SMALL	1.10.110.0005 sheet 1
297297	CIRCUIT IN COMMISSION NOTICE MAG	1.10.110.0005 sheet 1
297310	SINGLE CIRCUIT SECURITY MAGNETIC	1.10.110.0006 sheet 1
297307	SINGLE CIRCUIT SECURITY SMALL	1.10.110.0006 sheet 1
297308	SINGLE CIRCUIT SECURITY MEDIUM	1.10.110.0006 sheet 1
297311	PROTECTION ABNORMAL MAGNETIC	1.10.110.0007 sheet 1
297305	PROTECTION ABNORMAL MEDIUM	1.10.110.0007 sheet 1
297306	PROTECTION ABNORMAL SMALL	1.10.110.0007 sheet 1
297312	STOP THINK TAG	1.10.102.0014 sheet 1
321348	G78 CONNECTION POLE PLATE	1.09.107.0230 sheet 2
244015	FISHING WARNING NOTICE	1.09.101.0229 sheet 8
243953	FISHING PROHIBITION APPROACH NOTICE	1.09.101.0229 sheet 8
243954	FISHING PROHIBITION NOTICE	1.09.101.0229 sheet 8
362531	PREVENTION OF TRAGEDY NEDL SITE	1.02.108.0006 sheet 7
363445	RAILTRACK ROUTE MARKER OVERHEAD	1.09.101.0594 sheet 4
363483	RAILTRACK ROUTE MARKER OH. Tel NEDL	1.09.101.0594 sheet 4
363446	RAILTRACK ROUTE MARKER OH. Tel YEDL	1.09.101.0594 sheet 4
363464	RAILTRACK ROUTE MARKER UG	1.09.101.0594 sheet 5
362536	WARNING FOR RECREATIONAL SITES	1.09.101.0229 sheet 11
362535	PROHIBITION FOR RECREATIONAL SITES	1.09.101.0229 sheet 11
294827	CONFINED SPACES NOTICE	1.10.102.0022 sheet 1
294843	CONFINED SPACES ASSESSMENT RIGID	1.10.102.0023 sheet 1
294868	CONFINED SPACES ASSESSMENT S/A	1.10.102.0023 sheet 1
294173	ASBESTOS WARNING LABEL S/A	1.10.102.0024 sheet 1
294181	ASBESTOS WARNING LABEL RIGID	1.10.102.0024 sheet 1
294140	ASBESTOS CHECKED S/A	1.02.108.0007 sheet 1
294157	ASBESTOS CHECKED RIGID	1.02.108.0007 sheet 1
362540	ACCESS WARNING FIM LANDSCAPE XL	1.10.110.0009 sheet 1
362526	ACCESS WARNING FIM LANDSCAPE SMALL	1.10.110.0009 sheet 1
362538	ACCESS RESTRICTED NOTICE LARGE	1.10.110.0011 sheet 1
362529	ACCESS RESTRICTED NOTICE MEDIUM	1.10.110.0011 sheet 1
362537	OPERATIONAL FIM LARGE	1.10.110.0010 sheet 1

VOLTAGE PLATES

362917	433 V	1.02.112.0001 sheet 1
363040	5,500V	1.02.112.0001 sheet 1
362599	11,000V	1.02.112.0001 sheet 1
362584	20,000V	1.02.112.0001 sheet 1
362565	33,000V	1.02.112.0001 sheet 1
362550	66,000V	1.02.112.0001 sheet 1
367770	DANGER 33,000 VOLTS	1.09.101.0512 sheet 3
367747	DANGER 66,000 VOLTS	1.09.101.0512 sheet 2
362620	NEDL DANGER 132,000 VOLTS	1.09.101.0512 sheet 1
362532	YEDL DANGER 132,000 VOLTS	1.09.101.0512 sheet 8

Document reference		NPS/001/011					
Version:-	3	Date of Issue:-	Mar-07	Page	7	of	8

COMMODITY	DESCRIPTION	DRAWING
-----------	-------------	---------

SUBSTATION NAME PLATES

241040	NEDL DISTRIBUTION PROPERTY PLATE	1.02.108.0006 sheet 3
240226	NEDL PRIMARY PROPERTY PLATE	1.02.108.0006 sheet 4
362533	YEDL DISTRIBUTION PROPERTY PLATE	1.02.108.0008 sheet 2
362534	YEDL PRIMARY PROPERTY PLATE	1.02.108.0008 sheet 1

PHASE PLATES

363375	WOOD POLE -RED	1.09.101.0226 sheet 1
363394	WOOD POLE-YELLOW	1.09.101.0226 sheet 1
363407	WOOD POLE-BLUE	1.09.101.0226 sheet 1
363337	DOUBLE CIRCUIT TOWER-RED	1.09.101.0226 sheet 2
363356	DOUBLE CIRCUIT TOWER-YELLOW	1.09.101.0226 sheet 2
363360	DOUBLE CIRCUIT TOWER-BLUE	1.09.101.0226 sheet 2

NUMBER PLATES

243258	NUMBER BASE PLATE	1.09.101.0228 sheet 3
244369	NUMBER PLATE 1	1.09.101.0228 sheet 3
249697	NUMBER PLATE 2	1.09.101.0228 sheet 3
249714	NUMBER PLATE 3	1.09.101.0228 sheet 3
249729	NUMBER PLATE 4	1.09.101.0228 sheet 3
249733	NUMBER PLATE 5	1.09.101.0228 sheet 3
249748	NUMBER PLATE 6	1.09.101.0228 sheet 3
249752	NUMBER PLATE 7	1.09.101.0228 sheet 3
249767	NUMBER PLATE 8	1.09.101.0228 sheet 3
249771	NUMBER PLATE 9	1.09.101.0228 sheet 3
249786	NUMBER PLATE 0	1.09.101.0228 sheet 3
249324	NUMBER PLATE A	1.09.101.0228 sheet 3
249644	NUMBER PLATE B	1.09.101.0228 sheet 3
242664	POLE CONDITION PLATE "D"	1.09.101.0228 sheet 3
249339	NUMBER PLATE E	1.09.101.0228 sheet 3
242664	POLE CONDITION 'D' PLATE	1.09.101.0228 sheet 3
248745	BT ATTACHMENT LETTER A	1.09.119.3160 sheet 1
248764	BT ATTACHMENT LETTER B	1.09.119.3160 sheet 1
248571	BT ATTACHMENT LETTER C	1.09.119.3160 sheet 1
248567	BT ATTACHMENT LETTER J	1.09.119.3160 sheet 1
248618	BT ATTACHMENT NUMBER 1	1.09.119.3160 sheet 1
248622	BT ATTACHMENT NUMBER 2	1.09.119.3160 sheet 1
248637	BT ATTACHMENT NUMBER 3	1.09.119.3160 sheet 1
248641	BT ATTACHMENT NUMBER 4	1.09.119.3160 sheet 1
248656	BT ATTACHMENT NUMBER 5	1.09.119.3160 sheet 1
248660	BT ATTACHMENT NUMBER 6/9	1.09.119.3160 sheet 1
248675	BT ATTACHMENT NUMBER 7	1.09.119.3160 sheet 1
248726	BT ATTACHMENT NUMBER 8	1.09.119.3160 sheet 1
248730	BT ATTACHMENT NUMBER 0	1.09.119.3160 sheet 1

Document reference		NPS/001/011						
Version:-	3	Date of Issue:-	Mar-07	Page	8	of	8	

Appendix 2 – Supplier Requirements

Suppliers are required to provide evidence that the colour fastness of all outdoor signs meet the requirements of CE Electric UK (Section 3.2 and 3.3). Examples of evidence that may be acceptable could be test evidence or references from other similar customers.