

Document reference		NPS/ 001 / 013					
Version:-	3.0	Date of Issue:-	Jan -10	Page	1	of	8

NPS/001/013 – Technical Specification for Galvanised Steel Stay Wire

1. Purpose

The purpose of this document is to detail the technical specification for galvanised steel stay wire for use on the overhead line distribution networks of CE Electric UK.

This document supersedes the following documents, all copies of which should be destroyed.

Ref	Version	Title
DSS/004/009	1.0	Specification for Galvanised Steel Stay Wire
NEDL/MS – 0/31	1998	Technical Specification for Stay wire for Overhead Lines
NPS/001/013	2.0	Technical Specification for Galvanised Steel Stay Wire

2. Scope

This document applies to galvanised steel stay wire for use on the overhead line networks of CE Electric UK.

Document reference		NPS/ 001 / 013					
Version:-	3.0	Date of Issue:-	Jan -10	Page	2	of	8

2.1 Contents

1.	Purpose	1
2.	Scope	1
2.1	Contents	2
3.	Technical Requirements	3
4.	References	4
4.1	External Documentation	4
4.2	Internal documentation	4
4.3	Amendments from Previous Version	4
5.	Definitions	4
6.	Authority for issue	5
	Appendix 1 – Self Certification Conformance Declaration	6
	Appendix 2 – Addendum to Suppliers Requirements	8

Document reference		NPS/ 001 / 013					
Version:-	3.0	Date of Issue:-	Jan -10	Page	3	of	8

3. Technical Requirements

Galvanised steel stay wire shall be manufactured in accordance with Energy Networks Association Technical Specification (ENA TS) 43-91 Issue 5: 2004 – Stay Strands and Fittings for Overhead Lines.

The type of stay wire shall be 7/4.0mm stranding, grade 1150 and of a high tensile strength manufactured to BS183.

The galvanised steel stay wire shall have a specified minimum failing load of 101kN (10229kgf).

Document reference		NPS/ 001 / 013					
Version:-	3.0	Date of Issue:-	Jan -10	Page	4	of	8

4. References

4.1 External Documentation

Reference	Title
ENA TS 43-91 Issue 5: 2004	Stay Strands and Stay Fittings for Overhead Lines
BS183: 1972	Specification for General Purpose Galvanised Steel Stay Wire
BS EN 10218 – 1: 1994	Steel wire and wire products. Test Methods

4.2 Internal documentation

Reference	Title
-----------	-------

4.3 Amendments from Previous Version

Clause/Section	Subject	Amendments
----------------	---------	------------

5. Definitions

Term	Definition
------	------------

Document reference		NPS/ 001 / 013					
Version:-	3.0	Date of Issue:-	Jan -10	Page	5	of	8

6. Authority for issue

Written by:	Steven Salkeld	Standards Engineer	Steven Salkeld	21/01/2010
Technically assured by:	Richard McMahon	Standards Engineer	Richard McMahon	22/01/2010
CDS assured by:	Sean Johnson	CDS Administrator	Sean Johnson	27/01/2010
Authorised for Publication by:	Chris Holdsworth	Standards and Assessment Manager	Chris Holdsworth	21/01/2010

Document reference		NPS/ 001 / 013					
Version:-	3.0	Date of Issue:-	Jan -10	Page	6	of	8

Appendix 1 – Self Certification Conformance Declaration

Stay Wire covered by ENA TS 43-91 & BS 183 shall comply with the latest issues of the relevant international and British Standards.

ENA TS 43-91 is intended to amplify and/or clarify the requirements of those Standards.

This check sheet identifies the clauses in ENA TS 43-91 and the clauses of the aforementioned Standards relevant to stay wire for use on current United Kingdom designs of wood pole overhead lines.

The manufacturer shall declare conformance or otherwise, clause by clause, using the following levels of conformance declaration codes.

Conformance declaration codes

N/A = Clause is not applicable/ appropriate to the product

Cs1 = The product conforms fully with the requirements of this clause

Cs2 = The product conforms partially with the requirements of this clause

Cs3 = The product does not conform to the requirements of this clause

Cs4 = The product does not currently conform to the requirements of this clause, but the manufacturer proposes to modify and test the product in order to conform.

Manufacturer:

Product Reference:

Instructions for completion

- When Cs1 code is entered no remark is necessary
- When any other code is entered the reason for non-conformance shall be entered
- Prefix each remark with the relevant 'BS EN' or 'ENATS' as appropriate

Name:

Signature:

Date:

Document reference		NPS/ 001 / 013				
Version:-	3.0	Date of Issue:-	Jan -10	Page	7	of 8

BS 183			ENA TS 43– 91			Remarks
Clause / Sub-clause	Requirement	Confor- mance Code	Clause / Sub-clause	Requirement	Confor- mance Code	
5.1.1	Material					
5.1.2	Galvanised to BS 443; 1982					
5.2.1	Outer strand lay – right hand lay					
5.2.2	Lay length – 12 to 18 times nominal diameter.					
Table 3	Strand Size, diameter and minimum Failing Load of 7/4.00mm grade 1150		4.1	Strand Size, diameter and minimum Failing Load of 7/4.00 grade 1150		
6.0	Inspection and testing					

Document reference		NPS/ 001 / 013					
Version:-	3.0	Date of Issue:-	Jan -10	Page	8	of	8

Appendix 2 – Addendum to Suppliers Requirements

Stay wire shall be delivered in 50m coils with a maximum diameter of 900mm. A durable weatherproof label shall detail the following information: -

- CE Electric UK commodity code – 231481
- Material, grade and stranding configuration
- Gross package weight (kg)

The supplier shall complete the self declaration conformance codes in Appendix 1 of this specification.