

Document reference		NPS/002/007					
Version:-	1	Date of Issue:-	June 06	Page	1	of	7

NPS/002/007 – Technical Specification for Meter Boards and Outdoor Meter Cabinets

1. Purpose

The purpose of this document is to detail the specific requirements of NEDL and YEDL in relation to Meter Boards and Outdoor Meter Cabinets as detailed within this document.

This document supersedes the following documents, all copies of which should be destroyed.

Ref	Version	Title
DSS/005/003	1	Specification for Meter Boards
DSS/005/006	1	Specification for Exterior Meter Cabinets

2. Scope

This document applies to the supply of a range of meter boards and outdoor meter cabinets intended for use on the companies' distribution network for the service termination and metering equipment.

3. Requirements

3.1 Meter Boards

Meter boards shall be manufactured from 12mm thick class "O", non-combustible, resin-bonded chipboard of minimum density 700kg/m³.

3.2 Fixings

On a type 1 meter board (as detailed in Appendix 1), 6mm diameter fixing hole shall be so drilled to suit the fixing positions of a "small" outdoor cabinet as detailed in 3.4(below).

On type 2, 3 and 4 meter boards, 6mm diameter fixing hole are required 25mm from the edge of each board.

3.3 Meter Board Stand-off Insulators

Stand-off insulators shall be manufactured from a suitable insulating material. Each insulator shall be 19mm long x 19mm diameter with 8mm bore hole.

3.4 Recessed Meter Cabinets

The "Small" meter cabinet as detailed in ENATS 12-3 figure1 (b) ENATS drawing 120301, shall be constructed generally in glass reinforced thermoset plastic material. The material shall be substantially non-hygroscopic, must be resistant to normal environmental conditions, including ultraviolet radiation, dampness and abrasion.

Metal parts incorporated in the cupboard shall be manufactured from non-ferrous materials or suitably protected to prevent corrosion.

Where removable hinge pins are used, these shall be held captive with the door in the closed position.

Document reference		NPS/002/007					
Version:-	1	Date of Issue:-	June 06	Page	2	of	7

3.5 Cabinet Door

The cabinet door shall incorporate a “slam” type locking arrangement and comply generally with the shape and dimensions as shown in figure 1(a) drawing number 120301 of ENATS 12-3.

3.6 Cable Entry

Service cable entry is via a 38mm service duct which shall be surface mounted entering the cabinet architrave at the bottom left corner, as per drawing 120301 Fig1(b) of ENATS 12-3.

3.7 Dimensions

The cabinet shall comply generally with the shape and dimensions in figure 1(b) drawing number 120301 of ENATS 12-3.

3.8 Meter Board

The cabinet shall be supplied with a fitted meter board which shall be manufactured from 12mm thick class “O”, non-combustible, resin-bonded chipboard of minimum density 700kg/m³.

3.9 Surface mounted outdoor cabinet

The cabinet shall be constructed generally in glass reinforced thermoset plastic material. The material shall be substantially non-hygroscopic, must be resistant to normal environmental conditions, including ultraviolet radiation, dampness and abrasion.

Metal parts incorporated in the cupboard shall be manufactured from non-ferrous materials or suitably protected to prevent corrosion.

The cabinet shall be supplied complete with a fixed meter board, which shall be manufactured from 12mm thick class “O”, non-combustible, resin-bonded chipboard of minimum density 700kg/m³.

Service cable entry into the cabinet is via a 38mm service duct which shall be surface mounted and entering the cabinet at the rear, bottom left corner.

The door which shall be left hand hinged shall incorporate a “slam” type locking facility.

The overall dimensions of the cabinet shall be approximately 400mm wide x 600mm high x 220mm deep.

3.10 General

All meter cabinets and cabinet doors shall be manufactured and tested in accordance with ENATS 12-3.

Document reference		NPS/002/007					
Version:-	1	Date of Issue:-	June 06	Page	3	of	7

4. References

4.1 External Documentation

Reference	Title
ENATS 12-3 Issue 3 (1992)	Outdoor Meter Cupboards

4.2 Internal documentation

Reference	Title
NIL	

5. Definitions

Term	Definition
NIL	

Document reference		NPS/002/007					
Version:-	1	Date of Issue:-	June 06	Page	4	of	7

6. Authority for issue

6.1 Author

I sign to confirm that I have completed and checked this document and I am satisfied with its content and submit it for approval and authorisation.

		Sign	Date
R McMahon	Standards Engineer	R McMahon	03/04/06

6.2 Policy Sponsor

I sign to confirm that I am satisfied with all aspects of the content and preparation of this document and submit it for approval and authorisation.

		Sign	Date
G Bolden	Procurement Manager	G Bolden	23/05/06

6.3 Technical Assurance

I sign to confirm that I am satisfied with all aspects of the content and preparation of this document and submit it for approval and authorisation.

		Sign	Date
D M Gazda	Underground Standards Manager	D M Gazda	23/05/06

6.4 DBD Assurance

I sign to confirm that this document has been assured for issue on to the DBD system

		Sign	Date
S Johnson	DBD Administrator	S Johnson	31/03/06

6.5 Approval

Approval is given for the content of this document

		Sign	Date
C Holdsworth	Standards and Assessments Manager	C Holdsworth	23/05/06

6.6 Authorisation

Authorisation is granted for publication of this document

		Sign	Date
C Morgan	Head of Procurement	C Morgan	25/05/06

Document reference		NPS/002/007					
Version:-	1	Date of Issue:-	June 06	Page	5	of	7

Appendix 1 –Meter Board Sizes.

Type	Description	Size (mm) (H x W x D)	YEDL/NEDL Commodity Code
1	Standard Meter Board (Internal Meter Positions & outdoor cabinet replacement)	490 x 330 x 12	188135
2	Large Board (Internal 3-Phase Supplies)	560 x 450 x 12	188690
3	Chamfered Board (Three-Phase Supplies in Outdoor Meter Cabinets)	282 x 180 x12	181545
4	Small Meter Board	450 x 250 x 12	290734
-	External Meter Cabinet “Small”	595 x 409 x 210	188027
-	External Meter Cabinet “Surface Type”	600 x 400 x 220	181672

Document reference		NPS/002/007					
Version:-	1	Date of Issue:-	June 06	Page	6	of	7

Appendix 2 – Addendum to Supplier Requirements

Nil

Document reference		NPS/002/007					
Version:-	1	Date of Issue:-	June 06	Page	7	of	7

Appendix 3 – Logistical Requirements

The supplier shall ensure that each item is suitably packaged and protected to maintain the product and packaging as “fit for service” prior to installation.

Where items are provided in bagged/boxed form the material from which the bags are manufactured shall be capable of sustaining the package weight and resisting puncture by the materials within. Suppliers shall submit at the time of tendering the details of the proposed packaging (i.e. materials composition and structure) to be used for each product. Where the supplier is unable to provide packaging suitable for outdoor storage then this should be stated at the time of tender.

Palletised goods shall be supplied on standard 1200mm x 1000mm pallets.

Clearly legible, easily identifiable, durable and unambiguous labelling shall be applied to each individual and where relevant multiple package of like products. As a minimum requirement the following shall be included: -

- * Manufacturer's trademark or name
- * Supplier's trademark or name
- * Description of item
- * Date of packaging and/or batch number
- * CE Electric UK brand or name
- * CE Electric UK product code
- * Weight

To enable CE Electric UK to store the product(s) in accordance with the manufacturer's recommendations the supplier should provide details of the recommended storage environment with respect to each tendered product.