

Document reference		NPS / 002 / 013					
Version:-	1	Date of Issue:-	June 06	Page	1	of	7

NPS/002/013 – Technical Specification for Telephone and Pilot Cable Joints

1. Purpose

The purpose of this document is to specify the requirements of NEDL & YEDL in relation to Telephone and Pilot cable joints.

This document supersedes the following documents, all copies of which should be destroyed.

Ref	Version	Title
DSS/005/019	1	Specification for auxiliary cable jointing accessories

2. Scope

This document applies to joints intended for use on multipair and multicore auxiliary cables manufactured generally in accordance with ENATS 09-6. It is recognised, however, that it may be necessary to joint such cables of either a similar specification or to a specification which is now superseded.

3. Requirements

3.1 Test Criteria

When polythene insulated cables are jointed together, the system may be designed for either 5kV or 15kV induced voltage level. Since it is desirable that joints used on either system shall be interchangeable, the voltage tests required for these joints are those applicable to the 15kV system as detailed in ENATS C64 issue 2 – 2000.

3.2 Earth Connection

Earth connections and conductors will be suitable for carrying fault current and will be compatible with paper lead tape and wired armoured cables as well as P.V.C. wired armoured cables.

3.3 Joints

Joints will be required to connect XLPE/XLPE gel filled cable to XLPE/XLPE gel filled.

Joints will be required to connect XLPE/XLPE gel filled cable to PVC/XLPE.

Joints will be required to connect XLPE/XLPE gel filled cable to Paper lead.

3.4 Connectors

Connectors will be of the type to connect cores in single core configuration or as pairs. The connectors shall be of the type that does not require the removal of the core insulation and shall be self insulating.

3.5 Filling Medium

The joint when filled with filling medium i.e. resin shall still match the 15kV induced with stand voltage of the cable.

Document reference		NPS / 002 / 013					
Version:-	1	Date of Issue:-	June 06	Page	2	of	7

3.6 Kits

Joints kits shall contain all of the required components and including: -

Connectors

Joint shell

Resin

Earth braid

Assembly instructions.

Document reference		NPS / 002 / 013					
Version:-	1	Date of Issue:-	June 06	Page	3	of	7

4. References

4.1 External Documentation

Reference	Title
C64 issue 2 - 2000	Testing procedure for approval of joints for auxiliary cables

4.2 Internal documentation

Reference	Title
Nil	

5. Definitions

Term	Definition
NIL	

Document reference		NPS / 002 / 013					
Version:-	1	Date of Issue:-	June 06	Page	4	of	7

6. Authority for issue

6.1 Author

I sign to confirm that I have completed and checked this document and I am satisfied with its content and submit it for approval and authorisation.

		Sign	Date
R McMahon	Standards Engineer	R McMahon	03/04/06

6.2 Policy Sponsor

I sign to confirm that I am satisfied with all aspects of the content and preparation of this document and submit it for approval and authorisation.

		Sign	Date
G Bolden	Procurement Manager	G Bolden	23/05/06

6.3 Technical Assurance

I sign to confirm that I am satisfied with all aspects of the content and preparation of this document and submit it for approval and authorisation.

		Sign	Date
D M Gazda	Underground Standards Manager	D M Gazda	23/05/06

6.4 DBD Assurance

I sign to confirm that this document has been assured for issue on to the DBD system

		Sign	Date
S Johnson	DBD Administrator	S Johnson	31/03/06

6.5 Approval

Approval is given for the content of this document

		Sign	Date
C Holdsworth	Standards and Assessments Manager	C Holdsworth	25/05/06

6.6 Authorisation

Authorisation is granted for publication of this document

		Sign	Date
C Morgan	Head of procurement	C Morgan	25/05/06

Document reference		NPS / 002 / 013				
Version:-	1	Date of Issue:-	June 06	Page	5	of 7

Appendix 1 – Joint Requirements

Multi-Pair Joint Type					
Number of Pairs	Polythene to Polythene	Polythene to Impregnated Paper	Polythene to PVC	PVC to PVC	Polythene To Dry Paper
4	✓	✓	✓	✓	X
19	✓	✓	✓	✓	X
37	✓	✓	✓	✓	X
61	✓	✓	✓	✓	X

Multi-Pair Joint Type					
Number of cores	Polythene to Polythene	Polythene to Impregnated Paper	Polythene to PVC	PVC to PVC	Polythene To Dry Paper
4	✓	✓	✓	✓	X
19	✓	✓	✓	✓	X
37	✓	✓	✓	✓	X
61	✓	✓	✓	✓	X

Document reference		NPS / 002 / 013					
Version:-	1	Date of Issue:-	June 06	Page	6	of	7

Appendix 2 – Addendum to Supplier Requirements

To enable NEDL/YEDL to install the product(s) in accordance with the manufacturer's recommendations the supplier shall provide a single copy of drawings, descriptive leaflets and instruction manuals appropriate to the goods being offered, which shall incorporate details of the recommended installation procedures required in order to provide optimal performance of the goods during their operational life.

Document reference		NPS / 002 / 013					
Version:-	1	Date of Issue:-	June 06	Page	7	of	7

Appendix 3 – Logistical Requirements

The supplier shall ensure that each item is suitably packaged and protected to maintain the product and packaging as “fit for service” prior to installation taking account of the potential for an outdoor storage environment. All packaging shall be sufficiently durable giving regard to the function, reasonable use and contents of the packaging. Where product packages tendered are made up of sub packages all the sub packages shall unless varied by this specification, be supplied securely packaged together. Where items are provided in bagged/boxed form the material from which the bags are manufactured shall be capable of sustaining the package weight and resisting puncture by the materials within. Suppliers shall submit at the time of tendering the details of the proposed packaging (i.e. materials composition and structure) to be used for each product. Where the supplier is unable to provide packaging suitable for outdoor storage then this should be stated at the time of tender.

Palletised goods shall be supplied on standard 1200mm x 1000mm pallets.

Clearly legible, easily identifiable, durable and unambiguous labelling shall be applied to each individual and where relevant multiple package of like products. Where products packages tendered are made up of sub packages each sub packages shall be marked. As a minimum requirement the following shall be included: -

- * Manufacturer's trademark or name
- * Supplier's trademark or name
- * Description of item
- * Date of packaging and/or batch number
- * NEDL/YEDL brand or name
- * NEDL/YEDL product code
- * Weight