

Document reference		NPS / 002 / 027						
Version:-	1	Date of Issue:-	April 2010	Page	1	of	10	

NPS/002/027 – Technical Specification for Replacement Outdoor Meter Cupboard Frames and Doors.

1. Purpose

The purpose of this document is to detail the requirements of CE-Electric UK in relation to replacement outdoor meter cupboard doors and frames.

2. Scope

Outdoor meter cupboards in accordance with Energy Networks Association Technical Specification ENATS 12-3 have and continue to be used extensively for the installation of the electricity service termination and metering equipment.

Outdoor meter cupboards can suffer minor damage to doors, hinges and frames necessitating repair, and where replacement parts are no longer available the preferred solution is the installation of replacement unit comprising a new frame and door. This specification details the requirements, size and manufacturer type of outdoor meter cupboards for which replacement frames and doors are required.

Document reference		NPS / 002 / 027					
Version:-	1	Date of Issue:-	April 2010	Page	2	of	10

2.1. Contents

1.	Purpose.....	1
2.	Scope	1
2.1.	Contents	2
3.	Technical Requirements	3
3.1	Basic Parts.....	3
3.2	Dimensions	3
4.	References.....	4
5.	Definitions	4
6.	Authority for issue	5
Appendix 1 -	Requirements	6
Appendix 2 -	Addendum to Supplier Requirement	7
Appendix 3 -	Logistical requirements.....	8
Appendix 4 -	Self Certification Conformance Declaration.....	9

Document reference		NPS / 002 / 027					
Version:-	1	Date of Issue:-	April 2010	Page	3	of	10

3. Technical Requirements

3.1 Basic Parts

Replacement outdoor meter cupboard frames and doors shall as far as is reasonably practicable comply and match the sizes and types of cupboards in ENATS 12-3: Outdoor Meter Cupboards, detailed below in 3.2 and Appendix 1.

They shall be resistant to atmospheric corrosion, provided with a durable white protective finish and suitable for painting. Doors should be fitted with a robust "tri-head" lock, and supplied with a key, doors shall be removable and replaceable if required. Hinges shall be concealed. Frames and doors should meet or exceed the mechanical requirement of the original cupboard.

Frames and doors shall be supplied with the necessary fittings and fixings, and shall be easy to install by a competent person with a basic tool kit - no specialist tooling should be required.

3.2 Dimensions

The unit shall be supplied to fit cupboards - sizes and types as detailed below and in Appendix 1:-

- **Slimline** cupboard replacement frame and door: Suitable for Mitras Composites and Hampton Mouldings type cupboards.
- **Small** cupboard replacement frame and door: Suitable for Mitras Composites and Hampton Mouldings type cupboards.
- **Small** cupboard replacement frame and door: Suitable for Gloucester type cupboards.
- **Medium** cupboard replacement frame and door: Suitable for Mitras Composites, Hampton Mouldings and Gloucester type cupboards.
- **Large** cupboard replacement frame and door: Suitable for Hampton Mouldings type cupboards.

<u>Original Manufacturer / Cupboard Type and Overall Dimensions</u>				
Manufacturer / Type	Slimline	Small	Medium	Large
Mitras Composites	640 x 230 x 33mm	595 x 410 x 60mm	685 x 485 x 30mm	
Hampton Mouldings	830 x 280 x 60mm	595 x 410 x 60mm	682 x 487 x 35mm	795 x 565 x 33mm
Gloucester		612 x 426 x 33mm	690 x 493 x 45mm	

Document reference		NPS / 002 / 027						
Version:-	1	Date of Issue:-	April 2010	Page	4	of	10	

4. References

4.1 External Documentation

Reference	Title
ENATS 12-3	Outdoor Meter Cupboards

4.2 Internal documentation

Reference	Title

4.3 Amendments from Previous Version

Clause	Subject	Amendments

5. Definitions

Term	Definition
NIL	

Document reference		NPS / 002 / 027					
Version:-	1	Date of Issue:-	April 2010	Page	5	of	10

6. Authority for issue

6.1. Author

I sign to confirm that I have completed and checked this document and I am satisfied with its content and submit it for approval and authorisation.

		Sign	Date
V Gorny	Standards Engineer	V Gorny	08/04/2010

6.2. Technical Assurance

I sign to confirm that I am satisfied with all aspects of the content and preparation of this document and submit it for approval and authorisation.

		Sign	Date
R McMahon	Standards Engineer	R McMahon	08/04/2010

6.3. DBD Assurance

I sign to confirm that this document has been assured for issue on to the DBD system

		Sign	Date
S Johnson	DBD Administrator	S Johnson	14/04/2010

6.4. Authorisation

Authorisation is granted for publication of this document

		Sign	Date
C Holdsworth	Standards and Assessment Manager	C Holdsworth	08/04/2010

Document reference		NPS / 002 / 027					
Version:-	1	Date of Issue:-	April 2010	Page	6	of	10

Appendix 1 - Requirements

Requirements	CE Electric UK Commodity Code
Slimline cupboard replacement frame and door: Suitable for Mitras Composites and Hampton Mouldings type cupboards.	180275
Small cupboard replacement frame and door: Suitable for Mitras Composites and Hampton Mouldings type cupboards.	098046
Small cupboard replacement frame and door: Suitable for Gloucester type cupboards.	098012
Medium cupboard replacement frame and door: Suitable for Mitras Composites, Hampton Mouldings and Gloucester type cupboards.	098020
Large cupboard replacement frame and door: Suitable for Hampton Mouldings type cupboards.	098038

Document reference		NPS / 002 / 027						
Version:-	1	Date of Issue:-	April 2010	Page	7	of	10	

Appendix 2 - Addendum to Supplier Requirement

Supporting evidence of compliance with type tests shall be submitted with the completed tender document.

Manufacturers may provide alternative tenders for items not complying with the above specification. This shall be clearly stated together with detailed descriptions of any variation from the specification, together with drawings and test results.

The supplier shall provide with the tender full technical details of the equipment offered and shall indicate any divergence from these standards or specifications.

Document reference		NPS / 002 / 027					
Version:-	1	Date of Issue:-	April 2010	Page	8	of	10

Appendix 3 - Logistical requirements

To enable CE Electric UK to store the product(s) in accordance with the manufacturer's recommendations the Tenderer should provide details of the recommended storage environment with respect to each tendered product.

Details should be provided where relevant in respect to the minimum and maximum exposure levels, frequency of exposure and duration of exposure of the packaged item with respect to;

- | | | | |
|---|---------------------|---|-----------------------|
| * | Ambient temperature | * | Atmospheric corrosion |
| * | Humidity | * | Impact |
| * | Water | * | Vibration |
| * | Dust | * | Solar radiation |

The Tenderer shall ensure that each item is suitably packaged and protection to maintain the product and packaging as "fit for service" prior to installation taking account of the potential for an outdoor storage environment. All packaging shall be sufficiently durable giving regard to the function, reasonable use and contents of the packaging. Where product packages tendered are made up of sub packages all the sub packages shall unless varied by this specification, be supplied securely packaged together. Where items are provided in bagged/boxed form the material from which the bags are manufactured shall be capable of sustaining the package weight and resisting puncture by the materials within. Tenderer shall submit at the time of tendering the details of the proposed packaging (i.e. materials composition and structure) to be used for each product. Where the Tenderer is unable to provide packaging suitable for outdoor storage then this should be stated at the time of tender.

Palletised goods shall be supplied on standard 1200mm x 1000mm pallets.

Clearly legible, easily identifiable, durable and unambiguous labelling shall be applied to each individual and where relevant multiple packages of like products. Where products packages tendered are made up of sub packages each sub packages shall be marked. As a minimum requirement the following shall be included;

- * Manufacturer's trademark or name
- * Supplier's trademark or name
- * Description of item
- * Date of packaging and/or batch number
- * CE Electric UK product code
- * Weight

Tenderer shall submit at the time of tendering a sample of the proposed labelling for each product package type.

Document reference		NPS / 002 / 027						
Version:-	1	Date of Issue:-	April 2010	Page	9	of	10	

Appendix 4 - SELF CERTIFICATION CONFORMANCE DECLARATION

The Technical Specification for Replacement Outdoor Meter Cupboard Frame and Doors shall comply with the latest issues of the relevant national and international standards, including ENATS 12-3.

Additionally this technical specification is intended to amplify and/or clarify requirements relating to these Standards.

This self declaration sheet identifies the clauses of the aforementioned standards relevant to The Technical Specification for Replacement Outdoor Meter Cupboard Frame and Doors for use on the CE Electric UK distribution network. The manufacturer shall declare conformance or otherwise, clause by clause, using the following levels of conformance declaration codes.

Conformance declaration codes

N/A = Clause is not applicable/ appropriate to the product

Cs1 = The product conforms fully with the requirements of this clause

Cs2 = The product conforms partially with the requirements of this clause

Cs3 = The product does not conform to the requirements of this clause

Cs4 = The product does not currently conform to the requirements of this clause, but the manufacturer proposes to modify and test the product in order to conform.

Instructions for completion

- When Cs1 code is entered no remark is necessary
- When any other code is entered the reason for non- conformance shall be entered
- Prefix each remark with the relevant 'BS EN' 'IEC' or 'ENATS' as appropriate.

Manufacturer:

Product Reference:

Name:

Signature:

Date:

NOTE: One sheet shall be completed for each item or variant submitted.

Document reference		NPS / 002 / 027						
Version:-	1	Date of Issue:-	April 2010	Page	10	of	10	

Appendix 4 Cont'

Technical Specification for Replacement Outdoor Meter Cupboard Frame and Doors

• <u>NPS/002/027</u>			
Clause/Sub-clause	Requirement	Conformance Code	Remarks
3.1	Resistant to atmospheric corrosion		
	Provided with a durable white protective finish		
	Suitable for painting		
	Tri-head lock and key		
	Supplied with fixings		
3.2	Suitable for original manufactures cupboard size and type as detailed		
• <u>ENATS 12-3</u>			
3.3.1	Flammability Test (Appendix A)		
3.3.2	Mechanical Requirement		
4.4	Door Opening		
	Robust lock		
7	Easy replacement of doors, locks, hinges and hinge pins		