


	1	2	3	4	5	6	7	8
A	A3	LIST OF ALL RELEVANT DRAWINGS OR DOCUMENTS THAT DIRECTLY RELATE TO THE CURRENT REVISION OF THE DRAWING						A
B		DOCUMENT REFERENCE:						B
C		All Stay Assemblies; To ENATS 43-91 Issue 5. 1150/7/4.0. Type 2 stay block. Depth to stay block 2.0m						C
D		Denoted Thus;  Single						D
E								E
F								F
	1	2	3	4	5	6	7	8
	Intermediate		IHA	IHB	IHC			
	No. Of Stays	None		None	None			
	Soil Grades	4		3	2			
	Brace Baulk	1 No.		1 No.	1 No.			
	Top Baulks Btm Baulks	Type 3 - 2 No.		Type 4 - 2 No.	Type 4 - 4 No. Type 1 - 2 No.			
	Angle Support	Angle of deviation	0° - 45°	0° - 45°	0 - 45°			
	No. Of Stays	4 No. Req'd		4 No. Req'd	4 No. Req'd			
	Soil Grades	4		3	2			
	Brace Baulk	1 No.		1 No.	1 No.			
	Top Baulks	Type 3 - 2 No.		Type 4 - 2 No.	Type 4 - 4 No.			
	Angle of deviation	0°		0°	0°			
	No. Of Stays	4 No. Req'd		4 No. Req'd	4 No. Req'd			
	Soil Grades	4		3	2			
	Brace Baulk	1 No.		1 No.	1 No.			
	Top Baulks	Type 3 - 2 No.		Type 4 - 2 No.	Type 4 - 4 No.			
	Failure Containment		FCA	FCB	FCC			
	No. Of Stays	10 No.		10 No.	10 No.			
	Soil Grades	4		3	2			
	Brace Baulk	1 No.		1 No.	1 No.			
	Top Baulks	Type 3 - 2 No.		Type 4 - 2 No.	Type 4 - 4 No.			
	Terminal Poles		THA	THB	THC			
	No. Of Stays	No.		No.	No.			
	Soil Grades	4		3	2			
	Brace Baulk	No.		No.	No.			
	Top Baulks	Type 3 - No.		Type 4 - No.	Type 4 - No.			
	NOTE Terminal pole arrangements in abeyance. Awaiting confirmation of details.							
	1	2	3	4	5	6	7	8

Rev:	Drawn: PF	Approved: SA	Description:
01	Checked: DB	Date: 22-09-20	ISSUED FOR INFORMATION
 Scottish & Southern Electricity Networks			
SSE Inverlmond House, 200 Dunkeld Road Perth, PH1 3AQ, UKwww.sse.com			
Project: SSEN APPROACH 1 DESIGN			
Project Number: VARIOUS		Location: VARIOUS	
Title: INTERMEDIATE 'H' POLE ASSEMBLY 132kV WOOD POLE OHL			
Drawing Status: For Information		Drawn: PF	
Scale: NTS		Checked: DB	
Date: 12.01.20		Approved: SA	
Drawing Number: 200_1109_0039		Sheet No: 00	Revision No: 01