


Original issue
Date:- OCT 92
ISSUE 1
POLE MARKING &
ROOFING ADDED.
D.K.M. MAR 93



POLE LENGTH (m)	DIMENSION 'A'
8.5 TO 14	1300
15 TO 20	1600

FOR ASSEMBLY SEE DRG No. HO/37/2002
AND DRG No. HO/37/2003.

SCHEDULE A2001
33kV HEAVY CONSTRUCTION
SUPERSEDES DRG REF:- A2001

This drawing is protected by copyright and the information contained therein is confidential. The drawing may not be copied and the information contained therein may not be used, or disclosed to a third party wholly or in part except with the written permission of, and in the manner prescribed by SOUTHERN ELECTRIC plc c 1992 2

SSE Power Distribution

POLE DRILLING, SCARFING AND MARKING
SINGLE POLE

Scale:- N.T.S.	Dimensions in millimetres
Drn. by:- D.K.W.	Drawing no.
Tcd. by:- D.K.M.	HO /37 /2001
Ckd. by:- W.C.S.	C.A.D.Reference. HO2001.37
App. by:- W.C.S.	

A4P

DATE PLOTTED \$\$\$date\$\$\$