

Item no	Quantity lph	Quantity 3ph	Drawing/ Schedule Ref.	Description
001	04	04	19-201-9	INTERMEDIATE CROSSARM DC
002	02	02	19-202-2	INTERMEDIATE CROSSARM DC
003	06	06	19-212-9	END PLATE 33KV TWIN POLE
004	02	02	06-743-2	DANGER PLATE
005	21	02	06-100-9	M20 X 260 BOLT & NUT
006	04	04	06-101-2	M20 X 300 BOLT & NUT
007	12	12	06-085-9	M20 X 45 BOLT & NUT
008	01	01	E6002	BONDING KIT DRG REF A6002-1
009	02	02	G701	CIRCUIT IDENT PLATES TO G7-S4

Decision

010	01	01	C6002	DC DRILLING DETAILS TO A6002-2
011	03	06	G2-S35	33KV INSULATORS
012	03	06	G2-S36	33KV SPINDLES (CS)
013	01	01	G4-S11	TRUSSING TACKLE
014	03	06	G2-S34	33KV DISTRIBUTION TIES

Reminder

015	00	00	17-410-9	STAY BLOCK C/W NUT & BOLT
016	00	00	02-330-0	DENSO PASTE
017	00	00	02-336-8	UNIAL COMPOUND
018	00	00	11-669-5	DRIVE NAILS
019	00	00	11-899-8	PLASTIC WASHERS
020	00	00	06-971-9	BARBED WIRE
021	00	00	11-850-3	40 X 4 STAPLES
022	00	00	G7-S1	POLE NUMBER PLATES
023	00	00	06-952-8	20MM WASHERS

Total Cost 1/pole
A 6002 16m.
A 6004

Southern Electricity

Component Schedule for Drawing Ref:

App by R. C. NEWMAN

Issue 1 Date NOVEMBER 86

33KV INTER.DC 1800 SPACING

A6002

