

SP-NET-OHL-007	Specification for Wood Poles, Blocks and Associated Components		Applies to	
			Distribution	Transmission
Revision: 1.00	Classification: Internal	Issue Date: September 2021	✓	Review Date: September 2029

Original Issue
Date:- SEPT 86

ISSUE 2
REDRAWN ON CAD
AMENDED TO MUP
A.J.S. / W.C.S.
21.JUL.1993

POLE MARKING AND ROOFING TO DRAWING No. HO/39/4407

*** KICKING BLOCK:-**
EACH POLE IS TO BE SUPPLIED WITH, SCARFING, 22mm DIAMETER BOLT HOLE, BLOCK TO DRG No HO/38/331 AND COMPLETE WITH POLE BOLT, NUTS AND WASHERS.

OVERALL LENGTH AND DIA AS SPECIFIED

GOUGE MARK APPROX 6mm WIDE AND 6mm DEEP.

* SCARFING CUT TO GIVE 100mm FACE

* DRILLING 22mm DIAMETER

3000

255

'A'

INSPECTOR'S STAMP

POLE SIZE TO BE IMPRESSED ON POLE BUTT.

POLE LENGTH (m)	PLANTING DEPTH (m)	DIMENSION 'A'
8.5 TO 10.5	1.8	1300
11 TO 14	1.8	1300
OVER 14	2.1	1600

APPLICATION:- HO/37/8932, HO/37/8933

SCHEDULE A1019
LIGHT CONSTRUCTION
SUPERSEDES DRG REF:- A1019

This drawing is protected by copyright and the information contained therein is confidential. The drawing may not be copied and the information contained therein may not be used, or disclosed to a third party wholly or in part except with the written permission of, and in the manner prescribed by SOUTHERN ELECTRIC plc © 1986 2

SOUTHERN ELECTRIC

SINGLE POLE (UNDRILLED) WITH BLOCK

Scale:-	N.T.S.	Dimensions in millimetres
Des. by:-	D.K.W.	Drawing no.
Ycd. by:-	A.J.S.	HO /37 /1019
Ckd. by:-	W.C.S.	C.A.D. Reference. HO1019.37
App. by:-	W.C.S.	

DATE PLOTTED \$\$\$\$date\$\$\$