



1200 1200

11 12 3 21 7

24 25 1

100

3000

2 23 22 19

380

DIM 'B'

ADDITIONAL BLOCK TO BE FITTED WHERE REQUIRED

ANTI-SPLIT BOLTS AND TWO SQUARE-CURVED WASHERS TO BE FITTED ABOVE AND BELOW CROSSARM

23 19 19 22

14

NOTES:-

1. ALL DIMENSIONS ARE IN MILLIMETRES, UNLESS OTHERWISE SHOWN.
2. ALL POLE DRILLINGS ABOVE GROUND LEVEL WHICH ARE NOT USED, MUST BE PLUGGED WITH APPROVED WOOD POLE PLUGS
3. DIM 'B' IS SPECIFIC TO CONDUCTOR TYPE AND ENVIRONMENT.
SEE TABLE 11 OF RELEVANT APPENDIX FOR DETAILS

ScottishPower
Energy Networks

Drawn T.A.	Date 16/03/06
Checked L.C.	Date 19/04/06
Approved L.C.	Date 19/04/06
TRIS No.	

Type

GENERAL ASSEMBLY
INTERMEDIATE OR PIN ANGLE POLE

Location QHL SPEC

Voltage 11kV

FOR ISSUE

Drp No

SP2147473

Rev

2.0

Copyright property of SP PowerSystems Ltd.

Scale NTS

Size

Project

Rev
2.0

Date
01/03/07

Drawn T.A.	Checked L.C.
Approved L.C.	

DRG. TITLE AND NOTES AMENDED.



ScottishPower
EnergyNetworks

**Specification for 11kV And 33kV Overhead Lines of Unearthed Construction on Single
and “H” Type Wood Poles.**

OHL-03-099
Issue 1

Uncontrolled Copy

General Assembly Arrangement Single Pole Intermediate (Drawing SP2147473)

ITEM	NUMBER	DESCRIPTION	ENATS, BS or OTHER REFERENCE	DRAWING NUMBER	COMMODITY CODE NO.
01	1	Wood Pole	ENATS 434001	-	-
02	1 or 2	Pole Block	ENATS 439103 Type 2	SP4019020	C43810342
03	1	Intermediate Crossarm Member	ENATS 439519	SP4018402	C43811075
07	2	Crossarm Strut	ENATS 439526	SP4017649	C43811070
11	3	Insulator	ENATS 43-93	-	-
12	3	Insulator Pin	BS3288 Fig 4, Ref 29	-	C43270037
14	3	Helical Ties	ENATS 43-15	-	-
19	3 or 4	M20 Pole Bolt (HYS) and Nut. Length to suit Pole diameter	ENATS 43- 96 Clause 4.2 (Grade 8.8 HYS)	-	-
21	4	M20 x 60mm Assembly Bolt and Nut	ENATS 43- 96 Clause 4.2	-	C43602072
22	1 or 2	M20 Square Curved Washer	ENATS 439605	-	C43602025
23	3 or 4	M20 Square Flat Washer	ENATS 439604	-	C43602050
24	1 or 2	Safety Sign - English - Bilingual	- -	-	C06294004 C06293900
25	As Required	Pole Numbers	-	-	-
26	1	Insulator Bracket	ENATS 439518	SP4018449	C43811071
	As Required	Hardwood Plugs	ENATS 439516	-	-