





**ScottishPower**  
**EnergyNetworks**

**Specification for 11kV And 33kV Overhead Lines of Unearthed Construction on Single  
and “H” Type Wood Poles.**

**OHL-03-099**  
**Issue 1**

Uncontrolled Copy

**General Assembly Arrangement Single Pole Straight Line or Angle Section (Drawing reference SP2147476)**

| ITEM | NUMBER      | DESCRIPTION                                               | ENATS, BS or OTHER REFERENCE               | DRAWING NUMBER | COMMODITY CODE NO.     |
|------|-------------|-----------------------------------------------------------|--------------------------------------------|----------------|------------------------|
| 01   | 1           | Wood Pole                                                 | ENATS 434001                               | -              | -                      |
| 02   | 1 or 2      | Pole Block                                                | ENATS 439103 Type 2                        | SP4019020      | C43810342              |
| 04   | 2           | Section Crossarm Member                                   | ENATS 439520                               | SP4018433      | C43811077              |
| 07   | 4           | Crossarm Strut                                            | ENATS 439526                               | SP4017649      | C43811070              |
| 09   | 2           | Terminal Strap                                            | ENATS 439528                               | SP4017664      | C43811074              |
| 10   | 2           | Section Strap                                             | ENATS 439525                               | SP4017666      | C43811072              |
| 11   | 2           | Pin Insulator                                             | ENATS 43-93                                | -              | -                      |
| 13   | 2           | Pilot Pin 50mm Shank                                      | BS3288 Fig 5, Ref 50                       | -              | C43270177              |
| 14   | 2           | Helical Ties                                              | ENATS 43-15                                | -              | -                      |
| 15   | 6           | Ball End Hook                                             | BS3288 Fig 12 Ref 15/32                    | -              | C43238026              |
| 16   | 6           | Tension Insulator                                         | ENATS 43-93                                | -              | C43200548              |
| 17   | 6           | Helical Dead End Assembly                                 | ENATS 43-92                                | -              | -                      |
| 18   | 3           | Non Tension Joint                                         | -                                          | -              | -                      |
| 19   | 3 or 4      | M20 Pole Bolt (HYS) and Nut. Length to suit Pole diameter | ENATS 43- 96 Clause 4.2<br>(Grade 8.8 HYS) | -              | -                      |
| 20   | 2           | M20 Tie Rods                                              | ENATS 439608 Type 2 or 3                   | -              | C43811060              |
| 21   | 12          | M20 x 60mm Assembly Bolt and Nut                          | ENATS 43- 96 Clause 4.2                    | -              | C43602072              |
| 22   | 1 or 2      | M20 Square Curved Washer                                  | ENATS 439605                               | -              | C43602025              |
| 23   | 1 or 2      | M20 Square Flat Washer                                    | ENATS 439604                               | -              | C43602050              |
| 24   | 1 or 2      | Safety Sign English<br>Bilingual                          | -                                          | -              | C06294004<br>C06293900 |
| 25   | As Required | Pole Numbers                                              | -                                          | -              | -                      |
|      | As Required | Hardwood Plugs                                            | ENATS 439516                               | -              | -                      |