



The diagram illustrates the assembly of a pin angle pole. The side view shows a pole with a crossarm of length 1200mm. Callouts 11, 12, 3, 21, and 7 point to various components of the crossarm and pole. Callout 26 points to a bolt. The end view shows the pole with callouts 24, 25, and 1. A dimension of 100 is shown for the top section. The main pole length is 3000. Near the ground, callouts 2, 23, 22, and 19 point to components. A dimension of 380 is shown for the ground section. A note indicates 'DIM B' is specific to conductor type and environment. A detail view shows an 'ADDITIONAL BLOCK TO BE FITTED WHERE REQUIRED'. A top view shows the pole with callouts 27 and 21. A detail view shows the pole with callouts 23, 19, and 22. A note indicates 'ANTI-SPLIT BOLTS AND TWO SQUARE-CURVED WASHERS TO BE FITTED ABOVE AND BELOW CROSSARM'.

NOTES:-

1. ALL DIMENSIONS ARE IN MILLIMETRES, UNLESS OTHERWISE SHOWN.
2. ALL POLE DRILLINGS ABOVE GROUND LEVEL WHICH ARE NOT USED, MUST BE PLUGGED WITH APPROVED WOOD POLE PLUGS
3. DIM 'B' IS SPECIFIC TO CONDUCTOR TYPE AND ENVIRONMENT.
SEE TABLE 11 OF RELEVANT APPENDIX FOR DETAILS

Scottish Power
Energy Networks

Drawn T.A.	Date 01/03/07
Checked L.C.	Date 26/03/07
Approved L.C.	Date 26/03/07
TRIS No.	

Title

GENERAL ASSEMBLY
INTERMEDIATE OR PIN ANGLE POLE

Location QHL SPEC

Voltage 11kV/33kV

Status
FOR ISSUE

Dwg No
SP4018552

Rev

1.

Copyright property of SP PowerSystems Ltd.

Scale NTS

Size

Project

Rev	Date	Drawn	Checked	Approved



ScottishPower
EnergyNetworks

**Specification for 11kV And 33kV Overhead Lines of Unearthed Construction on Single
and “H” Type Wood Poles.**

OHL-03-099
Issue 1

Uncontrolled Copy

General Assembly Arrangement Single Pole Intermediate or Pin Angle (Drawing SP4018552)

ITEM	NUMBER	DESCRIPTION	ENATS, BS or OTHER REFERENCE	DRAWING NUMBER	COMMODITY CODE NO.
01	1	Wood Pole	ENATS 434001	-	-
02	1 or 2	Pole Block	ENATS 439103 Type 2	SP4019020	C43810342
03	2	Intermediate Crossarm Member	ENATS 439519	SP4018402	C43811075
07	4	Crossarm Strut	ENATS 439526	SP4017649	C43811070
11	3	Insulator	ENATS 43-93	-	-
12	3	Insulator Pin	BS3288 Fig 4, Ref 29	-	C43270037
14	3	Helical Ties	ENATS 43-15	-	-
19	3 or 4	M20 Pole Bolt (HYS) and Nut. Length to suit Pole diameter	ENATS 43- 96 Clause 4.2 (Grade 8.8 HYS)	-	Codes depend on bolt length
21	10	M20 x 60mm Assembly Bolt and Nut	ENATS 43- 96 Clause 4.2	-	C43602072
22	1 or 2	M20 Square Curved Washer	ENATS 439605	-	C43602025
23	1 or 2	M20 Square Flat Washer	ENATS 439604	-	C43602050
24	1 or 2	Safety Sign – English – Bilingual	-	-	C06294004 C06293900
25	As Required	Pole Numbers	-	-	-
26	1	Insulator Bracket	ENATS 439518	SP4018449	C43811071
27	2	Insulator Plate	-	SP4017637	C43500930
	As Required	Hardwood Plugs	ENATS 439516	-	-