


22.27 Figure 27 General Arrangement Transformer Stub Leg Platform 200kVA (Drawing No. SP4147881)



22.27.1 Schedule of Materials – Transformer Stub Leg Platform 200kVA (Drawing No. SP4147881)

ITEM	NUMBER	DESCRIPTION	ENA TS, BS or OTHER REFERENCE	DRAWING NUMBER
-	-	See General Arrangement for pole top materials relevant to conductor size and application	-	-
19	2	M20 Pole Bolt (HYS) and Nut. Length to suit Pole diameter	ENA TS 43-96 Clause 4.2 (Grade 8.8 HYS)	-
11	4	Insulator	ENA TS 43-93	-
13	1	Pilot Pin 50mm Shank	BS 3288 Fig 5, Ref 50	-
14	4	Helical Ties	ENA TS 43-15	-
24	1 or 2	Safety Sign - English - Bilingual	-	-
25	As Required	Pole Numbers	-	-
-	As Required	Hardwood Plugs	ENA Drawing No. 439516	-
42	2	30 Degree Angle Bracket	-	SP4018951
52	3	LV Fuses	-	-
53	3	Coach Screws	-	-
55	2	Platform – Transformer – “H” Pole	ENA Drawing No. 439524	-
56	2	Transformer Clamping Plate	ENA Drawing No. 439529	-
57	4	Bolt & Nut M20 x 100	ENA TS 43-96 Clause 4.2	-
58	4	Washer Round M20	ENA TS 43-96 Clause 4.2	-
59	1	Fuse crossarm	-	-
-	4	Coach Screws	-	-
-	2	Anti-climbing guard	ENA Drawing No. 439516	-
-	-	Barbed Wire	-	-