

EQUIPMENT SCHEDULE		
ITEM No.	DESCRIPTION	DRG. No.
1	CROSSARM 100 x 75 x 12mm. ANGLE	S18631 A
2	INSULATOR STOOL	S18160 S
3	TIE STRAP 50 x 50 x 8mm. ANGLE	S19658 D
4	LINE POST INSULATOR 33kV	S19114 R
5	CURVED WASHER FOR M20 DIA. BOLT	S19910 R
6	DANGER NOTICE	S19214 V
7	KICKING BLOCK 1200 x 200 x 100mm.	S18060 N
8	KICKING/BRACE BLOCK 2400 x 200 x 100mm.	S18057 R
9	NUMBER/LETTER PLATE	S19260-69 S19272-97
10	POLE TOP MAKE OFF	S19426 E
11	GUY GRIP DEAD END	S19427 H
12	STAY INSULATOR	S19162M
13	INSULATOR LINK	19400M
14	STAY WIRE	S19984 E
15	22mm DIA ADJUSTABLE STAY ROD	S19391K
16	STAY BLOCK	S180656
17	BARBED WIRE	S19977 X
18	STRAIGHT LINE STIRARUP	S19590 K
19	ANGLE STIRARUP	S19592 C
20	POLE	TO SPECIFICATION

B	29*0385	STAY INSULATOR CHANGED		HL	B
A	ORIGINAL				
Issue	Date	Revision	C.A.F.	Dm.	App.
			TO SCALE PRINT B1		
33kV Single Circuit Intermediate Pole					
SCALE 1:20			C.A.F.		
DRAWING NO. B1000				ISSUE C	
SITE		Standard Drawings			

