

DESIGN NOTES:-
FOR 200 SQ.mm (18/1/3-86) A.C.S.R. FOR SPANS OF
BARE CONDUCTOR UP TO 170m AND SPANS OF P.V.C.
COVERED CONDUCTOR UP TO 150m.
FOR STRAIGHT LINE POSITIONS AND ANGLES OF
DEVIATION UP TO 5°

EQUIPMENT SCHEDULE		
ITEM No.	DESCRIPTION	DRG. No.
1	CROSSARM 100 x 75 x 10 mm. ANGLE.	S.18635.K
2	LINE POST INSULATOR – 33 kV.	S.19114.R
3	LINE POST INSULATOR MOUNTING PLATE.	S.19228.N
4	M20 DOUBLE ENDED STUD.	S.17770.Y
5	DANGER NOTICE	S.19214.V
6	BRACE BLOCK, 2100 x 200 x 100 mm.	S.18059.J
7	CURVED WASHER FOR M20 DIA. BOLT.	S.19910.R
8	NUMBER / LETTER PLATE.	S.19260-69 S.19272-97
9	POLE TOP MAKE OFF	S.19426E
10	GUY GRIP DEAD END	S.19427.N
11	STAY INSULATOR.	S.19162.M
12	INSULATOR LINK	19400.M
13	STAY WIRE	S.19984.E
14	22mm DIA ADJUSTABLE STAY ROD	S.19391.K
15	STAY BLOCK	S.18065.B
16	STRAIGHT LINE STIRRUP.	S.19590.K
17	ANGLE STIRRUP.	S.19592.C
18	BARBED WIRE	S.19977.X
19	POLE	TO SPECIFICATION

B	29.3.85	STAY INSULATOR CHANGED		H.L. J.P.
A	13-12-77	REDRAWN TO METRIC DIMENSIONS-DRG. No. WAS 4/ A7.		MAC
Issue	Date	Revision	C.A.F.	Dr. Ap

eastern electricity 

ENGINEERING DIVISION

33 kV SINGLE CIRCUIT
H THROUGH POLE

SCALE 1:20

DRAWING NO. 4/B1001

ISSUE	B
-------	---

