

NOTE:-  
THIS ARRANGEMENT TO BE USED AT STRAIGHT  
LINE POSITIONS ONLY.

## EQUIPMENT SCHEDULE

| ITEM No. | DESCRIPTION                                           | DRG. No.                 |
|----------|-------------------------------------------------------|--------------------------|
| 1        | POLE                                                  | TO SPECIFICATION         |
| 2        | TEE-OFF CROSSARM                                      | S.18750 L                |
| 3        | 10" (254mm) DISC INSULATOR                            | S.19042 S                |
| 4        | LINE POST INSULATOR - 33kV                            | S.19114 R                |
| 5        | DEAD END CLAMP FOR 200sq mm. A.C.S.R.                 | S.20207 V                |
| 6        | BALL ENDED HOOK                                       | S.19003 V                |
| 7        | SOCKET TONGUE                                         | S.18040 X                |
| 8        | CROSSARM STRAP                                        | S.19681 Q                |
| 9        | TRUSSING TACKLE                                       | S.18148 W                |
| 10       | WARNING NOTICE                                        | S.19197 D                |
| 11       | DANGER NOTICE                                         | S.19214 V                |
| 12       | NUMBER / LETTER PLATE                                 | S.19260-69<br>S.19272-97 |
| 13       | KICKING BLOCK 1200 x 200 x 100 mm                     | S.18060 N                |
| 14       | CURVED WASHER FOR 1/2" DIA. BOLTS                     | S.19910 R                |
| 15       | POLE TOP MAKE OFF                                     | S.19426 E                |
| 16       | GUY G/P DEAD END                                      | S.19427 N                |
| 17       | STAY INSULATOR                                        | S.19158 G                |
| 18       | STAY WIRE                                             | S.19984 E                |
| 19       | 22mm. DIA. ADJUSTABLE STAY ROD                        | S.19391 K                |
| 20       | STAY BLOCK                                            | S.18065 G                |
| 21       | BARBED WIRE                                           | S.19977 X                |
| 22       | RECOVERED 0.1in <sup>2</sup> (7.136) H.B. BARE COPPER | 052990                   |
| 23       | 70mm <sup>2</sup> (19/2.14) S.D. BARE ANNEALED COPPER | 0-3-74                   |
| 24       | STRAIGHT LINE STIRAP                                  | S.19590 K                |
| 25       | COMPRESSION CONNECTOR                                 | 21215 N                  |
| 26       | INSULATOR STOOL                                       | S.18160 S                |

|       |          |          |                  |
|-------|----------|----------|------------------|
| A     | 14-12-77 | ORIGINAL | MAC              |
| Issue | Date     | Revision | C.A.T. D.H. App. |

eastern electricity

CHIEF ENGINEERS' DEPARTMENT

33kV SINGLE CIRCUIT  
TEE-OFF FROM  
SINGLE POLE.

SCALE 1:20

DRAWING NO.

4/B1004

