

EQUIPMENT SCHEDULE		
ITEM No.	DESCRIPTION	DRG.No.
	POLE	TO SPECIFICATION
2	CROSSARM 2 - 102 x 51 x 10.42 kg/m CHANNEL - 4670 mm. LONG.	S18643A
3	CROSSARM 2 - 102 x 51 x 10.42 kg/m. CHANNEL - 5890mm. LONG.	S18642R
4	LINE POST INSULATOR 33 kV	S19114R
5	LINE POST INSULATOR MOUNTING PLATE	S19228N
6	M20 DOUBLE ENDED STUD	S17770Y
7	CIRCUIT IDENTIFICATION PLATES	S19184U
8	WARNING NOTICE	S19197D
9	DANGER NOTICE	S19214V
10	NUMBER/LETTER PLATE	S19260-6/ S19272-Z
11	KICKING/BRACE BLOCK 2400 x 200 x 100mm.	S18057R
12	CURVED WASHER FOR M20 DIA. BOLTS	S19910 R
13	POLE TOP MAKE OFF	S19426E
14	GUY GRIP DEAD END	S19427N
15	STAY INSULATOR	S19162M
16	INSULATOR LINK	I9400M
17	STAY WIRE	S19984E
18	22mm. DIA. ADJUSTABLE STAY ROD	S19391K
19	STAY BLOCK	S18065G
20	STRAIGHT LINE STIRRUP	S19590K
21	ANGLE STIRRUP	S19592C
22	32mm (3/3.75) H.D. BARE COPPER	05291 V
23	COPPER LUG	21137R

B	28.3.85	STAY INSULATOR CHANGED.	JS. J.N.
A	10.1.80	REDRAWN TO METRIC DIMENSIONS. DRG. No WAS 4/A8	M.C. D.W.

eastern electricity 

ENGINEERING DIVISION

33 kV. DOUBLE CIRCUIT
(UNEARTHED)
INTERMEDIATE POLE

1:20

4 / B1093

