

5/B189

APPLICATION
FOR 100sqmm (6/4.72 + 7/157) ACSR.
MAXIMUM SPAN 165m BARE, 145m PVC
COVERED.

EQUIPMENT SCHEDULE		
ITEM No.	DESCRIPTION	DRG. No.
1.	POLE	
2.	CROSSARM 2 - 100 x 75 x 10mm M.S. ANGLE.	S18750L
3.	TENSION STRAP.	S19714S
4.	DISC INSULATOR.	S19042S
5.	BALL ENDED HOOK.	S19003V
6.	SOCKET TONGUE.	S18040K
7.	CONDUCTOR TERMINATING CLAMP.	S20202C
8.	DANGER NOTICE.	S19214V
9.	NUMBER / LETTER PLATE.	S19260-69 S19272-97
10.	PHASE IDENTIFICATION PLATE.	S19231K/2T/3C
11.	BRACE BLOCK, 2400 x 200 x 100mm.	S18057R
12.	STAYWIRE.	S19984E
13.	STAY INSULATOR.	S19163V
14.	POLE TOP MAKE OFF.	S19426E
15.	GUY GRIP DEAD END.	S19427W
16.	LINE SPLICE.	S19432C
17.	ADJUSTABLE STAY ROD.	S19391K
18.	STAY BLOCK.	S18065G
19.	11kV CABLE BOX.	
20.	11kV CABLE BOX MOUNTING PLATE.	S18155D
21.	CABLE SADDLE.	S20113P/4X/5G
22.	11kV PIN TYPE INSULATOR.	S19075R
23.	PILOT INSULATOR PIN.	S19456C
24.	STIRRUP BINDING.	S19585V
25.	BARBED WIRE.	S19977X
26.	ANTI-CLIMBING BRACKET.	S18916R
27.	TYPE 8 PVC COVERED 14mm ² (7/1.60) COPPER CONDR.	05508B
28.	EARTH WIRE GUARD.	S18942E
29.	CABLE GUARD.	S18920W/32W
30.	EXTENSIBLE EARTH ROD.	S19355P
31.	EARTH ROD DRIVING POINT.	S19357G
32.	EARTH ROD COUPLING.	S19359Y
33.	BULL DOG GRIP.	S19358Q
34.	11kV SURGE DIVERTER.	
35.	SURGE DIVERTER MOUNTING PLATFORM.	S18237K
36.	CURVED WASHER FOR M20 BOLT.	S19910R
37.	COACH SCREW 3" x 5/8" DIA.	17041E
38.	50mm ² FLEXIBLE ALUMINIUM.	05957X
39.	LIVE LINE TAP.	S2040CE
40.	ALUMINIUM LUG.	S21119T
41.	BI-METAL LUG.	S21174V/79P
42.	COPPER CEE TAPS (CRIMPIT).	S21200M
43.	DENSO TAPE.	S12891R

FOR SCHEDULE OF NUTS AND BOLTS REQUIRED, REFER TO OHL MANUAL SECT. 7/8.

DRILLINGS

POLES TO BE SCARFED FOR A DISTANCE
OF 230mm FROM POLE TOP TO GIVE A WIDTH
OF 150mm BETWEEN FACES.

THIS DRILLING REQUIRED
ONLY ON ONE POLE.


DRILLINGS AND MARKINGS

- ALL HOLES TO BE 22mm DIA. UNLESS OTHERWISE STATED.
- 75 x 6 x 6mm GOUGE MARK 300mm UP FROM BUTT ON INSIDE OF LEGS.
- BUTT TO BE SAWN OFF SQUARE TO THE AXIS OF THE POLE.
- POLE TO BE MARKED AS PER INSET.
- IT IS ESSENTIAL THAT THE DRILLINGS ARE DRILLED TO TEMPLATE, ARE ACCURATE AND DEAD CENTRE.
- LEGS OF H POLE TO BE CAREFULLY MATCHED.
- THE FOLLOWING INFORMATION TO BE IMPRESSED ON END GRAIN OF BUTT OF POLE.

- (a) LENGTH AND DIAMETER OF POLE.
(b) POLE NUMBER IN ACCORDANCE WITH SCHEDULE.

NOTE: THE PERSONAL MARK OF THE POLE INSPECTOR
WILL BE IMPRESSED ON THE BUTT.

TYPICAL MARKINGS FOR WOOD POLES.



POLE TO BE SCARFED
TO GIVE A 100mm FACE.

1300mm FOR POLES UP TO
AND INCLUDING 14m
1500mm FOR POLES OVER 14m

EARTHING NOTE.
WHERE A POLE BOX OR OTHER HIGH VOLTAGE
APPARATUS IS MOUNTED ON THE POLE, ALL
STEELWORK SHALL BE BONDED AND EARTHED
BY TYPE 8 PVC COVERED 14mm² (7/1.60)
COPPER CONDUCTOR.
BONDING AND EARTHING CONNECTIONS SHALL
CLAMPED BETWEEN STEEL SURFACES AND NOT
BETWEEN STEELWORK AND POLE.
THE CONNECTION BETWEEN THE EARTH ROD AND THE
CONDUCTOR SHALL BE BY MEANS OF ONE BULL DOG
GRIP.
THE CONNECTION SHALL BE PROTECTED FROM CORROSION
BY THE APPLICATION OF AT LEAST TWO LAYERS OF
'DENSO' TAPE (ITEM 43 IN EQUIPMENT SCHEDULE).

BARBED WIRE TO BE FITTED
WHERE TWO OR MORE STAYS ARE
ARRANGED IN SUCH PROXIMITY TO
ONE ANOTHER AS TO FACILITATE
CLIMBING.

1800mm FOR POLES UP TO
AND INCLUDING 14m.
2100mm FOR POLES OVER 14m.

TYPE A

TYPE B

TYPE A

TYPE B
(FOR ABNORMAL
SITE CONDITIONS)

A	16.11.83	REVISED DESIGN WITH METRIC DIMENSIONS	HL	AS
ISSUE	DATE	REVISION	CAF	DRG APP
eastern electricity				
ENGINEERING DIVISION				
11kV HEAVY CONSTRUCTION TERMINAL 'H' POLE.				
SCALE 1 : 20				
DRAWING No. 5/B189				
ISSUE A				