




NOTE:-



EQUIPMENT SCHEDULE

ITEM No.	DESCRIPTION	DRG. No.
1	POLE	S.18634 B
2	CROSSARM	S.19042 S
3	10" (254mm) DISC INSULATOR	S.20202 C
4	CONDUCTOR TERMINATING CLAMP	S.19003 V
5	BALL ENDED HOOK	S.18040 X
6	SOCKET TONGUE	S.18250 P
7	SEALING END SUPPORTING BRACKET	S.18222 J
8	SEALING END BATTENS	18 050 F
9	SEALING END	S.19221 C
10	SEALING END CONNECTOR PLATE	S.18632 J
11	SUPPORTING STEELWORK FOR SURGE DIVERTERS	S.18633 S
12	SURGE DIVERTER	S.18412K-3T
13	GUSSET PLATE	S.18406-9
14	BACKBOARD AND CLEAT CROSSARM	S.19214 V
15	CLEAT SUPPORTING CHANNEL	S.18222 J
16	SINGLE WAY CABLE CLEAT (NEOPRENE INSERT)	S.18222 J
17	TREFOIL CABLE CLEAT (SINGLE BOLT FIXING)	S.18222 J
18	DANGER NOTICE	S.18222 J
19	NUMBER / LETTER PLATE	S.18222 J
20	PHASE IDENTIFICATION PLATES	S.18222 J
21	ANTI-CLIMBING BRACKET	S.18222 J
22	BARBED WIRE	S.18222 J
23	BRACE BLOCK, 2100 x 200 x 100mm	S.18222 J
24	CABLE GUARD, 3000mm LONG	S.18222 J
25	WOOD BACKBOARD, 4200 x 250 x 50mm	S.18222 J
26	POLE TOP MAKE OFF	S.18222 J
27	LINE SPLICE	S.18222 J
28	STAY WIRE	S.18222 J
29	GUY GRIP DEAD END	S.18222 J
30	STAY INSULATOR	S.18222 J
31	22mm DIA ADJUSTABLE STAY ROD	S.18222 J
32	STAY BLOCK	S.18222 J
33	PVC EARTH WIRE GUARD 2400mm LONG	S.18222 J
34	BULL DOG GRIP (2 No REQD.)	S.18222 J
35	COUPLING	S.18222 J
36	1500mm LONG EXTENSIBLE EARTH ROD	S.18222 J
37	DRIVING POINT	S.18222 J
38	COPPER CRIMPIT	S.18222 J
39	CABLELOK CRIMPIT	S.18222 J
40	ALUMINIUM LUG	S.18222 J
41	ALUMINIUM LUG	S.18222 J
42	BI-METAL LUG	S.18222 J
43	BI-METAL STRAIGHT	S.18222 J
44	RECOVERED 0.1in ² (7.136) H.D. BARE COPPER	S.18222 J
45	70mm ² (19/2.14) S.D. BARE ANNEALED COPPER	S.18222 J
46	70mm ² (19/2.14) P.V.C. COVERED ANNEALED COPPER	S.18222 J
47	100mm ² (7/4.39) BARE ALUMINIUM	S.18222 J
48	ALUMINIUM STRIP (40x6mm AL ALLOY-EIE-M TOB'S 2898)	S.18222 J
49	'DENSO' TAPE, 50mm WIDE	S.18222 J
50	CURVED WASHER FOR M20 DIA. BOLTS	S.18222 J
51		

C	01.04.1985	STAY INSULATOR ADDED	JS
B	10.03.1982	TERMINATING CLAMP CHANGED	CB
		CABLE TREFOIL	JS
		EARTH REPOSITIONED	
REDRAWN TO METRIC DIMS. DRG. NO. WAS 4/A6 (MAC)			
A	14/12/1977	ORIGINAL	MAC
Version	Date	DESCRIPTION	Drawn

33kV TERMINAL POLE
SEALING END ARRANGEMENT

SCALE	1:20	@ A0	AS REJECTED	Checked	Version
DRAWING NO.	B1007				
SITE	Standard Drawings				