

MATERIALS LIST.

Item	Nº	Commodity Code	Description	Drawing or Ref. Number	M 20 Bolts	Washers		
						sc	sf	r
3	2	BPC 024	Wood Pole (type 1A)	Y204 L 0601				
30	1	222455	Crossarm Member	Y204 L 0902	2 x 300			
60	6		33kV Tension Set	Y204 L 0704				
			66kV Tension Set					
70	2	294181	Safety Sign	Y201 L 1002				
71			Operational Plates	Y201 L 1001/7				
45	1	219519	Pole Bracing (Single)	Y 204 L 0905				
		219501	Pole Bracing (Double)					
19	2	217497	Brace Block	Y204 L 0301	4(Pole)	4	4	

Notes to drawing Nº Y104 L 0113.


1. Single pole bracing required for poles up to 14.0m.

Double pole bracing required for poles 15.0m and above.

Pole Planting Depth	
Pole Length (m)	Dim S (m)
<=11.5	1.80
12.0 - 13.0	2.00
14.0 - 15.0	2.10
16.0 - 17.0	2.25
18.0 - 20.0	2.40

Area:
 File: Plotted on: by:

Copyright of YORKSHIRE ELECTRICITY GROUP plc. No part of this drawing to be reproduced without prior permission.



DIMENSIONS IN MILLIMETRES

drawn	GR	CE/C/37 (M1) SECTION			Y104L0113	CAD	 Yorkshire Electricity
traced	RLH						
checked							
approved							
revision	B	date	18.5.98	original scale	NTS		