



NOTES

- 1 POLES TO BE 'STOUT CLASS' TO BS 1990, CREOSOTED TO BS 913 BY RUEPING PROCESS, AFTER DRILLING & SCARFING
- 2 POLES TO BE MATCHED FOR H STRUCTURES, EACH PAIR OF POLES TO BE MARKED WITH IDENTICAL PAIRING NUMBERS
- 3 MINIMUM POLE TOP DIAMETER 215mm
- 4 ALL HOLES 22 DIA UNLESS STATED OTHERWISE DRILLED AT RIGHT ANGLES TO VERTICAL CENTRE LINE OF POLE
- 5 FOR ARRANGMENT DRG SEE Y208L0101

POLE LENGTH (M)	DIMENSION 'A' (mm)	DIMENSION 'B' (mm)
11.0	1370	1480
12.0	1530	1760

DIMENSIONS IN MILLIMETRES

drawn	MHJ
	9/12/90
traced	
checked	NF
approved	BT
revision	

POLE FABRICATION
33kV POLYMERIC CABLE TERMINATION
WITH TYPE HEC 36 SURGE DIVERTERS
CE/C/36 (M)

date 27/12/00 original Y203L0601

CAD



Yorkshire
Electricity