

EXTERIOR WALL ASSEMBLIES

WALL TYPE NO.	WALL ASSEMBLY (PLAN)	CONSTRUCTION	MINIMUM EFFECTIVE R-VALUE	NOTES
WC1		WINDOW WALL SYSTEM 150 mm / 150 mm RAISED ALUMINUM BYPASS PANELS GALVANIZED INSULATED BACK PAN SELF-ADHERED VAPOUR PERMEABLE AIR BARRIER MEMBRANE REINFORCED CAST-IN-PLACE CONCRETE PARAPET SELF-ADHERED VAPOUR PERMEABLE AIR BARRIER MEMBRANE VERTICAL SUPPORT SYSTEM FIBRE CEMENT CLADDING	N/A	PARAPET OVER WINDOW WALL
		PREFINISHED METAL CLADDING CONCEALED FINING SYSTEM PER CLADDING MANUFACTURER THERMALLY BROKEN CLIPS @ 400 mm O.C. MAX. 50 mm SEM-RIGID ROCK WOOL INSULATION LIQUID-APPLIED DAMPPROOFING MEMBRANE 80 mil. DRY FILM THICKNESS 6 mil. POLYETHYLENE VAPOUR BARRIER (SEE STRUCTURAL) 6 mil. POLYETHYLENE VAPOUR BARRIER STEEL FURRING TO ALIGN WITH BACKUP WALL ABOVE 16 mm TYPE 'X' GYPSUM WALLBOARD	N/A	EXTERIOR WALL ASSEMBLY AT CONCRETE PARAPETS OVER EXTERIOR METAL CLAD STUD WALL FRESHEN COLOUR AND FINISH TO MATCH ADJACENT WW PANEL
WC3		CONCRETE FACED INSULATION BOARD DRAINAGE MAT AND FILTER CLOTH LIQUID-APPLIED DAMPPROOFING MEMBRANE 80 mil. DRY FILM THICKNESS 6 mil. POLYETHYLENE VAPOUR BARRIER (SEE STRUCTURAL) 6 mil. POLYETHYLENE VAPOUR BARRIER STEEL FURRING TO ALIGN WITH BACKUP WALL ABOVE 16 mm TYPE 'X' GYPSUM WALLBOARD	PER ENERGY REPORT	L1 CURB
WG1		CURTAIN WALL SYSTEM 150 mm / 150 mm RAISED ALUMINUM PANELS GALVANIZED INSULATED BACK PAN	PER ENERGY REPORT	SEE ARCHITECTURAL PLANS, ELEVATIONS, SECTIONS, AND DETAILS FOR LOCATION OF INSULATED GLASS PANELS TYP. AT L1 STREET FRONT ELEVATIONS AND ENTRIES
WG2		WINDOW WALL SYSTEM 150 mm / 150 mm RAISED ALUMINUM PANELS GALVANIZED INSULATED BACK PAN	PER ENERGY REPORT	SEE ARCHITECTURAL PLANS, ELEVATIONS, SECTIONS, AND DETAILS FOR LOCATION OF INSULATED GLASS PANELS 100 mm DEPTH AT PODIUM, 50 mm DEPTH AT TOWER
WE1		PREFINISHED METAL CLADDING CONCEALED FINING SYSTEM PER CLADDING MANUFACTURER THERMALLY BROKEN CLIPS @ 400 mm O.C. MAX. 50 mm SEM-RIGID ROCK WOOL INSULATION LIQUID-APPLIED DAMPPROOFING MEMBRANE 80 mil. DRY FILM THICKNESS 6 mil. POLYETHYLENE VAPOUR BARRIER (SEE STRUCTURAL) 6 mil. POLYETHYLENE VAPOUR BARRIER STEEL FURRING TO ALIGN WITH BACKUP WALL ABOVE 16 mm TYPE 'X' GYPSUM WALLBOARD	PER ENERGY REPORT	PODIUM EXTERIOR STUD WALL COLOUR AND FINISH TO MATCH ADJACENT WW PANEL
WE2		FIBRE CEMENT CLADDING CONCEALED ANCHORS HORIZONTAL RAIL SYSTEM VERTICAL SUPPORT SYSTEM THERMALLY BROKEN CLIP SYSTEM 50 mm SEM-RIGID MINERAL WOOL INSULATION SELF-ADHERED VAPOUR PERMEABLE AIR BARRIER MEMBRANE 16 mm GLASS MAT FACED GYPSUM SHEATHING 152 mm STRUCTURAL METAL STUDS ROCK WOOL BATT INSULATION (R-20 / 3.5 RS) 6 mil POLY VAPOUR BARRIER 16 mm GYPSUM WALLBOARD TYPE 'X'	PER ENERGY REPORT	PODIUM EXTERIOR WALL RIBBED / FLUTED OPIC PANELS, CONCEALED CLIPS
WE3		FIBRE CEMENT CLADDING CONCEALED ANCHORS HORIZONTAL RAIL SYSTEM VERTICAL SUPPORT SYSTEM THERMALLY BROKEN CLIP SYSTEM 50 mm SEM-RIGID MINERAL WOOL INSULATION SELF-ADHERED VAPOUR PERMEABLE AIR BARRIER MEMBRANE 16 mm GLASS MAT FACED GYPSUM SHEATHING 152 mm STRUCTURAL METAL STUDS ROCK WOOL BATT INSULATION (R-20 / 3.5 RS) 6 mil POLY VAPOUR BARRIER 16 mm GYPSUM WALLBOARD TYPE 'X'	PER ENERGY REPORT	PODIUM EXTERIOR WALL RIBBED / FLUTED OPIC PANELS, CONCEALED CLIPS
WE4		PREFINISHED METAL CLADDING CONCEALED FINING SYSTEM PER CLADDING MANUFACTURER THERMALLY BROKEN CLIPS @ 400 mm O.C. MAX. 50 mm SEM-RIGID MINERAL WOOL INSULATION LIQUID-APPLIED DAMPPROOFING MEMBRANE 80 mil. DRY FILM THICKNESS 6 mil. POLYETHYLENE VAPOUR BARRIER (SEE STRUCTURAL) 6 mil. POLYETHYLENE VAPOUR BARRIER STEEL FURRING TO ALIGN WITH BACKUP WALL ABOVE 16 mm TYPE 'X' GYPSUM WALLBOARD	PER ENERGY REPORT	3 HOUR RATED EXTERIOR WALL ULC DESIGN NO. U415 COLOUR AND FINISH TO MATCH ADJACENT WW PANEL
WE5		FIBRE CEMENT CLADDING CONCEALED ANCHORS HORIZONTAL RAIL SYSTEM VERTICAL SUPPORT SYSTEM THERMALLY BROKEN CLIP SYSTEM 50 mm SEM-RIGID MINERAL WOOL INSULATION SELF-ADHERED VAPOUR PERMEABLE AIR BARRIER MEMBRANE 16 mm GLASS MAT FACED GYPSUM SHEATHING 152 mm STRUCTURAL METAL STUDS ROCK WOOL BATT INSULATION (R-20 / 3.5 RS) 6 mil POLY VAPOUR BARRIER 16 mm GYPSUM WALLBOARD TYPE 'X'	PER ENERGY REPORT	2 HOUR RATED EXTERIOR WALL ULC DESIGN NO. U415 RIBBED / FLUTED OPIC PANELS, CONCEALED CLIPS
WM1		FIBRE CEMENT CLADDING CONCEALED ANCHORS HORIZONTAL RAIL SYSTEM VERTICAL SUPPORT SYSTEM THERMALLY BROKEN CLIP SYSTEM 50 mm SEM-RIGID MINERAL WOOL INSULATION SELF-ADHERED VAPOUR PERMEABLE AIR BARRIER MEMBRANE 16 mm GLASS MAT FACED GYPSUM SHEATHING 152 mm STRUCTURAL METAL STUDS ROCK WOOL BATT INSULATION (R-20 / 3.5 RS) 6 mil POLY VAPOUR BARRIER 16 mm GYPSUM WALLBOARD TYPE 'X'	PER ENERGY REPORT	PODIUM EXTERIOR WALL AT MOMENT FRAME RIBBED / FLUTED OPIC PANELS, CONCEALED CLIPS
WM2		FIBRE CEMENT CLADDING CONCEALED ANCHORS HORIZONTAL RAIL SYSTEM VERTICAL SUPPORT SYSTEM THERMALLY BROKEN CLIP SYSTEM 50 mm SEM-RIGID MINERAL WOOL INSULATION SELF-ADHERED VAPOUR PERMEABLE AIR BARRIER MEMBRANE 16 mm GLASS MAT FACED GYPSUM SHEATHING 152 mm STRUCTURAL METAL STUDS ROCK WOOL BATT INSULATION (R-20 / 3.5 RS) 6 mil POLY VAPOUR BARRIER 16 mm GYPSUM WALLBOARD TYPE 'X'	N/A	TERRACE EXTERIOR WALL BEHIND WINDOW WALL AT MOMENT FRAME
WEF1		38 mm CLEARANCE GAP 64 mm METAL STUDS 16 mm GYPSUM WALLBOARD TYPE 'X'	N/A	BACK-UP WALL ASSEMBLY
WEF2		38 mm CLEARANCE GAP 64 mm METAL STUDS 16 mm GYPSUM WALLBOARD TYPE 'X'	N/A	BACK-UP LOUVER ASSEMBLY

INTERIOR WALL ASSEMBLIES

WALL TYPE NO.	WALL ASSEMBLY (PLAN)	CONSTRUCTION	FIRE RATING	STC RATING	NOTES
P1		16 mm GYPSUM WALLBOARD TYPE 'X' 152 mm STEEL STUDS AT 400 mm O.C. 92 mm BATT INSULATION 16 mm GYPSUM WALLBOARD TYPE 'X'	NA	47 BCBC 2024 9.10.3.1-A WALL TYPE 54b	INTERIOR, NON-BEARING, UNRATED WALL TYPICAL PARTITION STC 38 WITHOUT 92 mm ACOUSTIC BATT INSULATION - 9.10.3.1-A WALL TYPE 54b
P2		2 LAYERS 16 mm GYPSUM WALLBOARD TYPE 'X' 152 mm STEEL STUDS AT 400 mm O.C. 92 mm BATT INSULATION 16 mm GYPSUM WALLBOARD TYPE 'X'	1 HR BCBC 2024 D-2.5.4	52 BCBC 2024 9.10.3.1-A WALL TYPE 55b	INTERIOR, NON-BEARING, RATED WALL JUNT ENTRY PARTITION
P3		16 mm GYPSUM WALLBOARD TYPE 'X' 152 mm STEEL STUDS AT 400 mm O.C. 92 mm BATT INSULATION 16 mm GYPSUM WALLBOARD TYPE 'X'	NA	51 BCBC 2024 9.10.3.1-A WALL TYPE 57a	INTERIOR, NON-BEARING, UNRATED WALL PLUMBING PARTITION STC 41 WITHOUT 152 mm ACOUSTIC BATT INSULATION - 9.10.3.1-A WALL TYPE 57a
P4		2 LAYERS 16 mm GYPSUM WALLBOARD TYPE 'X' 152 mm STEEL STUDS AT 400 mm O.C. 92 mm BATT INSULATION 16 mm GYPSUM WALLBOARD TYPE 'X'	1 HR BCBC 2024 D-2.5.4	52 BCBC 2024 9.10.3.1-A WALL TYPE 55b	INTERIOR, NON-BEARING, RATED WALL TYPICAL CORRIDOR PARTITION
P5		3 LAYERS 16 mm GYPSUM WALLBOARD TYPE 'X' 152 mm STEEL STUDS AT 400 mm O.C. 92 mm BATT INSULATION 16 mm GYPSUM WALLBOARD TYPE 'X'	3 HR ULC DESIGN NO. U415	56 BCBC 2024 9.10.3.1-A WALL TYPE 56b	INTERIOR, NON-BEARING, RATED WALL TYPICAL CORRIDOR PARTITION
P6		2 LAYERS 16 mm GYPSUM WALLBOARD TYPE 'X' 152 mm STEEL STUDS AT 400 mm O.C. 92 mm BATT INSULATION 16 mm GYPSUM WALLBOARD TYPE 'X'	3 HR ULC DESIGN NO. U415	56 BCBC 2024 9.10.3.1-A WALL TYPE 56b	INTERIOR, NON-BEARING, RATED WALL TYPICAL CORRIDOR PARTITION
P7		16 mm GYPSUM WALLBOARD TYPE 'X' 152 mm STEEL STUDS AT 400 mm O.C. 92 mm BATT INSULATION 16 mm GYPSUM WALLBOARD TYPE 'X'	NA	51 BCBC 2024 9.10.3.1-A WALL TYPE 57a	INTERIOR, NON-BEARING, UNRATED WALL PLUMBING PARTITION STC 41 WITHOUT 152 mm ACOUSTIC BATT INSULATION - 9.10.3.1-A WALL TYPE 57a
P8		2 LAYERS 16 mm GYPSUM WALLBOARD TYPE 'X' 64 mm STEEL STUDS AT 400 mm O.C. 92 mm BATT INSULATION 64 mm AIR SPACE 64 mm BATT INSULATION 16 mm GYPSUM WALLBOARD TYPE 'X'	1 HR BCBC 2024 D-2.5.4	51 BCBC 2024 9.10.3.1-A WALL TYPE 57a	INTERIOR, NON-BEARING, RATED WALL SUITE TO SUITE SEPARATION WALL STAGGER STUDS WHERE POSSIBLE NO BACK-TO-BACK PENETRATIONS
P9		2 LAYERS 16 mm GYPSUM WALLBOARD TYPE 'X' 64 mm STEEL STUDS AT 400 mm O.C. 92 mm BATT INSULATION 64 mm AIR SPACE 64 mm BATT INSULATION 16 mm GYPSUM WALLBOARD TYPE 'X'	2 HR ULC DESIGN NO. X517 SM	56 NRC BOOKS 768	INTERIOR, BEARING, RATED WALL SUITE TO CORRIDOR SEPARATION WALL STAGGER STUDS WHERE POSSIBLE NO BACK-TO-BACK PENETRATIONS
PF1		42 mm STEEL STUDS @ 400 mm O.C. MAX. 2 LAYERS 16 mm GYPSUM WALLBOARD TYPE 'X'	2 HR ULC DESIGN NO. X517	NA	STRUCTURAL STEEL PROTECTION
PF2		64 mm STEEL STUDS @ 400 mm O.C. MAX. 16 mm GYPSUM WALLBOARD TYPE 'X'	NA	NA	TYPICAL WALL FURRING
PF3		92 mm STEEL STUDS @ 400 mm O.C. MAX. 16 mm GYPSUM WALLBOARD TYPE 'X'	NA	NA	TYPICAL WALL FURRING
PF4		152 mm STEEL STUDS @ 400 mm O.C. MAX. 16 mm GYPSUM WALLBOARD TYPE 'X'	NA	NA	PLUMBING WALL FURRING
PF5		152 mm STEEL STUDS @ 400 mm O.C. MAX. 16 mm GYPSUM WALLBOARD TYPE 'X'	NA	NA	PLUMBING WALL FURRING
PS1		25 mm GYPSUM WALLBOARD SHAFT LINER 64 mm C-H STUDS @ 600 mm O.C. 92 mm BATT INSULATION 16 mm GYPSUM WALLBOARD TYPE 'X'	1 HR UL U415 SYSTEM A	35 UL U415	PROPRIETARY SHAFTWALL ASSEMBLY TYPICAL 1 HOUR SHAFT WALL
PS2		25 mm GYPSUM WALLBOARD SHAFT LINER 64 mm C-H STUDS @ 600 mm O.C. 92 mm BATT INSULATION 2 LAYERS 16 mm GYPSUM WALLBOARD TYPE 'X'	2 HR UL U415 SYSTEM B	40 UL U415	PROPRIETARY SHAFTWALL ASSEMBLY TYPICAL 2 HOUR SHAFT WALL
PS3		25 mm GYPSUM WALLBOARD SHAFT LINER 64 mm C-H STUDS @ 600 mm O.C. 92 mm BATT INSULATION 2 LAYERS 16 mm GYPSUM WALLBOARD TYPE 'X'	2 HR UL U415 SYSTEM B	40 UL U415	PROPRIETARY SHAFTWALL ASSEMBLY TYPICAL 2 HOUR SHAFT WALL
PS4		16 mm GYPSUM WALLBOARD TYPE 'X' 25 mm GYPSUM WALLBOARD SHAFT LINER 152 mm C-H STUDS @ 600 mm O.C. 92 mm BATT INSULATION 16 mm GYPSUM WALLBOARD TYPE 'X'	2 HR UL U415 SYSTEM B	40 UL U415	PROPRIETARY SHAFTWALL ASSEMBLY TYPICAL 2 HOUR SHAFT WALL
PB1		150 mm REINFORCED CONCRETE BLOCK TYPE N/S. GRADED SOLID	3 HR UL U415 NOTE 2	50 BCBC 2024 TABLE 9.10.3.1-A WALL TYPE 51a SM	INTERIOR, NON-BEARING, RATED WALL SERVICE ROOMS / BIKE ROOMS L1 ONLY

Date 14/25-03-2024

Issued for BPHF Check Out

Issued for Cladding Changes

Rev Date

25-01-31

Drawing File

Drawn By

RCI/MZM

Checked By

ACM

Scale

1 : 10

Project Number

1922

NOTE: All dimensions are shown in millimeters

View St. Residential

937 View Street

Wall Assemblies

Schedule

dhKa

A701

dhK Architects

777 Fort Street

Vib 3K3

T1-250-658-3367

Nansimo

102-5180 Dublin Way

Vib 4H2

T1-250-585-5810

COPYRIGHT RESERVED. THESE PLANS AND SPECIFICATIONS ARE THE PROPERTY OF dhK ARCHITECTS. THEY ARE NOT TO BE REPRODUCED WITHOUT THEIR CONSENT.

THE PROPERTY OF dhK ARCHITECTS IS TO BE USED FOR THE PROJECT SHOWN AND MAY NOT BE REPRODUCED WITHOUT THEIR CONSENT.