

PLANT SERVICES MANUAL - SECTION 2

Chilled water plant

Building A was recommissioned in
March by Hartley Mechanical.

Its chilled water setpoint is
6.5 degrees.

Its condenser approach is
1.2 degrees.

Building B was recommissioned in
August by Hartley Mechanical.

Its chilled water setpoint is
9.0 degrees.

Its condenser approach is
2.8 degrees.

Table 2.1 - Contractor rates by trade and shift

Rates are in dollars per hour, excluding GST.

Trade	Weekday		Weekend		Public holiday	
	Normal	Overtime	Normal	Overtime	Normal	Overtime
Electrical	96	144	120	180	168	252
Plumbing	88	132	110	165	154	231
Rigging	104	156	130	195	182	273

Overtime applies after eight hours on any shift.