SSE/POWER ANDHERI

MUMBAI DIVISION WESTERN RAILWAY

Subject: **AI Smart Energy Saving Device Report**

Respected Sir,

I, DEVENDRA UMESH CHAVAN, POST GRADUATED in Data Science. Working on an Artificial Intelligence Smart Energy Saving Device for Indian Railways.

I have Demonstrated Smart Device on a single Fan at Andheri Railway Station on Platform No 4 for 1 month. Device Automatically Switch OFF the Fan if not in use

Installed device on 8 January 2024 to 8 Feb 2024

Fan Power ON (6.30 am to 1.30 am)

POWER SAVING Report for **1 Month** (80 watt fan)

Total Power Consumed

	Ordinary Fan	Fan with (SMART DEVICE)
WATT	**47,120**	**18,200**
UNITS	**47.1**	**18.2**

Total Energy SAVED

WATT	**28,920**
UNITS	**28.9**

Total Electricity **Saved 28.9 units** in 1 month **(61.4 %)** as compare to other Fan total electricity consumption without Smart Device Installed

Scanned with OKEN Scanner

Power Saving Cost Calculation

Unit Rate	Units Saved	Monthly Saving	Yearly Saving
8.1 ₹	28.9	234 ₹	2,808 ₹

Return on Investment (ROI)

Product Cost (Approx)	2000 ₹	2500 ₹	3000 ₹
Month's	9	11	13

Thank You

Yours Sincerely

Devendra Chavan

09/02/2024

SSE/POWER ANDHERI

अनुभाग अभियंता (विद्युत/शक्ति)
पश्चिम रेल अंधेरी
Section Engineer (Elect./Power)
W. Rly. Andheri

Scanned with OKEN Scanner