


LEGEND:



PRESSURIZATION FAN




DAMPER



SUPPLY AIR GRILL

GENERAL NOTES:

1. ALL SUPPLY DUCT DIMENSIONS ARE IN MM.
2. THE PRESSURE DIFFERENCE ACROSS THE DOOR BETWEEN THE PRESSURIZED SPACE AND ACCOMMODATION AREA ON FIRE STOREY SHALL NOT LESS THAN 50 ± 10 PA.



PRESSURIZATION FAN RISER DIAGRAM

SCALE

NTS



BatStateU
BATANGAS STATE UNIVERSITY
Gov. Pablo Borbon Main Campus II
Alangilan, Batangas City
MECHANICAL ENGINEERING DEPARTMENT

PROJECT LEADER	INSTRUCTOR	PROJECT / LOCATION:	OWNER	PREPARED BY:	No.	REVISIONS	DATE	SHEET CONTENT	SHEET NO.
ENGR. MARK KERVIN N. ABU MECHANICAL ENGINEER	ENGR. ALLAN B. DE VILLA PROFESSIONAL MECHANICAL ENGINEER	PROPOSED THREE STOREY HOSPITAL	TEAM ABU	ABU, MARK KERVIN N.	1	DRAWING DETAILS	12/10/2019	PRESSURIZATION FAN RISER DIAGRAM	M
SECTION: ME - 5103	PRC Reg No.			AZUCENA, RONIEL A.	2	DRAWING DETAILS	12/22/2019		19
GROUP NO: 12	TIN:			CASTILLO, JOHN ADRIAN M.	3	DRAWING DETAILS	01/07/2020		
DATE SUB: JANUARY 07, 2020	Issued on:	BATANGAS CITY	ENGR. RONIEL A. AZUCENA PRESIDENT						
	Issued at:								