


LEGENDS



GENERAL NOTES:

- THIS DRAWING SHOWS THE GROUND FLOOR EXHAUST LAYOUT.
- ALL DIMENSION ARE IN M UNLESS OTHERWISE SPECIFIED.
- THE MECHANICAL CONTRACTOR SHALL BE RESPONSIBLE FOR ALL THE BALANCING, TESTING, AND COMMISSIONING OF THE WHOLE AIR CONDITIONING AND VENTILATION SYSTEM.



GROUND FLOOR EXHAUST LAYOUT

SCALE

1:400

EXHAUST FAN SCHEDULES

UNIT NO.	QTY	SERVICE	CAPACITY (L/S)	Pressure (kPa)	MAX. INPUT WATTS	ELECTRICAL CHARACTERISTIC	RPM
EXHF-01	10	TOILET EXHAUST	45	0.34	17.60	0.15/ 115 V/ 60	900
EXHF-06	4	TOILET EXHAUST	192	0.34	121	0.15/ 115 V/ 60	1000



BatStateU
BATANGAS STATE UNIVERSITY
Gov. Pablo Borbon Main Campus II
Alangilan, Batangas City
MECHANICAL ENGINEERING DEPARTMENT

PROJECT LEADER	INSTRUCTOR	PROJECT / LOCATION:	OWNER	PREPARED BY:	No.	REVISIONS	DATE	SHEET CONTENT	SHEET NO.
ENGR. MARK KERVIN N. ABU MECHANICAL ENGINEER	ENGR. ALLAN B. DE VILLA PROFESSIONAL MECHANICAL ENGINEER	PROPOSED THREE STOREY HOSPITAL	TEAM ABU	ABU, MARK KERVIN N.	1	DRAWING DETAILS	12/10/2019	GROUND FLOOR EXHAUST LAYOUT	<div>M 12</div>
SECTION: ME - 5103	PRC Reg No.			AZUCENA, RONIEL A.	2	DRAWING DETAILS	12/22/2019		
GROUP NO: 12	TIN:			CASTILLO, JOHN ADRIAN M.	3	DRAWING DETAILS	01/07/2020		
DATE SUB: JANUARY 07, 2020	Issued on:	BATANGAS CITY	ENGR. RONIEL A. AZUCENA PRESIDENT						