



## LEGENDS

EXHAST FANS

### GENERAL NOTES:

- THIS DRAWING SHOWS THE SECOND FLOOR EXHAUST LAYOUT.
- ALL DIMENSION ARE IN M UNLESS OTHERWISE SPECIFIED.
- THE MECHANICAL CONTRACTOR SHALL BE RESPONSIBLE FOR ALL THE BALANCING, TESTING, AND COMMISSIONING OF THE WHOLE AIR CONDITIONING AND VENTILATION SYSTEM.

### EXHAUST FAN SCHEDULES

UNIT NO.	QTY	SERVICE	CAPACITY (L/S)	Pressure (KPa)	MAX. INPUT WATTS	ELECTRICAL CHARACTERISTIC	RPM
EXH-F-01	27	TOILET EXHAUST	45	0.34	17.60	0.15/115 V 60	900

M  
13

## SECOND FLOOR EXHAUST LAYOUT

SCALE

1:400



**BatStateU**  
BATANGAS STATE UNIVERSITY  
Gov. Pablo Borbon Main Campus II  
Alangilan, Batangas City  
MECHANICAL ENGINEERING DEPARTMENT

PROJECT LEADER	INSTRUCTOR	PROJECT / LOCATION:	OWNER	PREPARED BY:	No.	REVISIONS	DATE	SHEET CONTENT	SHEET NO.
ENGR. MARK KERVIN N. ABU MECHANICAL ENGINEER	ENGR. ALLAN B. DE VILLA PROFESSIONAL MECHANICAL ENGINEER	PROPOSED THREE STOREY HOSPITAL	TEAM ABU	ABU, MARK KERVIN N.	1	DRAWING DETAILS	12/10/2019	SECOND FLOOR EXHAUST LAYOUT	M 13
SECTION: ME - 5103	PRC Reg No.			AZUCENA, RONIEL A.	2	DRAWING DETAILS	12/22/2019		
GROUP NO: 12	TIN:			CASTILLO, JOHN ADRIAN M.	3	DRAWING DETAILS	01/10/2020		
DATE SUB: JANUARY 10, 2020	Issued on:	BATANGAS CITY	ENGR. RONIEL A. AZUCENA PRESIDENT						
	Issued at:								