

## LEGENDS

EXHAUST FANS


### GENERAL NOTES:

- THIS DRAWING SHOWS THE SECOND FLOOR EXHAUST LAYOUT.
- ALL DIMENSION ARE IN M UNLESS OTHERWISE SPECIFIED.
- THE MECHANICAL CONTRACTOR SHALL BE RESPONSIBLE FOR ALL THE BALANCING, TESTING, AND COMMISSIONING OF THE WHOLE AIR CONDITIONING AND VENTILATION SYSTEM.

### EXHAUST FAN SCHEDULES

UNIT NO.	QTY	SERVICE	CAPACITY (L/S)	Pressure (kPa)	MAX. INPUT WATTS	ELECTRICAL CHARACTERISTIC	RPM
EXH-F-01	27	TOILET EXHAUST	45	0.34	17.60	0.15/115 V 60	900

## SECOND FLOOR EXHAUST LAYOUT



SCALE

1:400



**BatStateU**  
BATANGAS STATE UNIVERSITY  
Gov. Pablo Borbon Main Campus II  
Alangilan, Batangas City  
MECHANICAL ENGINEERING DEPARTMENT

PROJECT LEADER		INSTRUCTOR		PROJECT / LOCATION:		OWNER		PREPARED BY:		No.	REVISIONS	DATE	SHEET CONTENT	SHEET NO.
ENGR. MARK KERVIN N. ABU MECHANICAL ENGINEER		ENGR. ALLAN B. DE VILLA PROFESSIONAL MECHANICAL ENGINEER		PROPOSED THREE STOREY HOSPITAL		TEAM ABU		ABU, MARK KERVIN N.		1	DRAWING DETAILS	12/10/2019		
SECTION: ME - 5103		PRC Reg No.		PTR No.		ENGR. RONIEL A. AZUCENA PRESIDENT		AZUCENA, RONIEL A.		2	DRAWING DETAILS	12/22/2019	SECOND FLOOR EXHAUST LAYOUT	M 14
GROUP NO: 12		TIN:		Issued on:		BATANGAS CITY		CASTILLO, JOHN ADRIAN M.						
DATE SUB: DECEMBER 22, 2019				Issued at:										