


LEGEND:



GENERAL NOTES:

- 1. ALL SUPPLY DUCT DIMENSIONS ARE IN MM.
- 2. THE PRESSURE DIFFERENCE ACROSS THE DOOR BETWEEN THE PRESSURIZED SPACE AND ACCOMMODATION AREA ON FIRE STOREY SHALL NOT LESS THAN $50\pm10~\text{PA}$.





| PROJECT LEADER | INSTRUCTOR | | PROJECT / LOCATION: | OWNER | PREPARED BY: | No. | REVISIONS | DATE CONTENT | SHEET NO. |
|----------------------------|---|------------|--------------------------------|--------------------------------------|--------------------------|-----|-----------------|---|---------------|
| | | | | | | 1 | DRAWING DETAILS | 12/10/2019 SHEET CONTENT | SHEET NO. |
| ENGR. MARK KERVIN N. ABU | ENGR. ALLAN B. DE VILLA PROFESSIONAL MECHANICAL ENGINEER | | PROPOSED THREE STOREY HOSPITAL | TEAM ABU | ABU, MARK KERVIN N. | 2 | DRAWING DETAILS | 12/22/2019 PRESSURIZATION FAN RISER DIAGRAM | |
| MECHANICAL ENGINEER | | | | | | 3 | DRAWING DETAILS | 01/10/2020 | $ M \rangle$ |
| | | | | | AZUCENA, RONIEL A. | | | | |
| SECTION: ME - 5103 | PRC Reg No. | PTR No. | | | AZUCENA, NONIEE A. | | | | 19 |
| GROUP NO: 12 | TIN: | Issued on: | BATANGAS CITY | ENGR. RONIEL A. AZUCENA PRESIDENT | CASTILLO, JOHN ADRIAN M. | | | | |
| DATE SUB: JANUARY 10, 2020 | | Issued at: | BATANGAS CITY | | | | | | |