DOC. N.° 1SQC900015M0201

ReliaGear® neXT Panelboard

Replacement Part Instructions



WARNING
Danger of electrical shock or injury. Turn OFF power ahead of the panel board or switchboard before working inside the equipment or removing any component. Equipment is to be installed and maintained by properly trained and qualified personnel only.



a. Panelboard accessories may not be field installed in the wiring space of the enclosure panelboard unless the conductors, splices, taps and equipment at any cross section of the wiring space does not exceed 75 percent of the cross-sectional area of that space.


b. Accessories shall not block enclosure ventilation openings.

c. Accessories shall not block the breaker arc vents.

		Kit Catalog Number	Qty.
A		RGRPDPIN	6X
B		RGRPTSCR	10X
C		RGRPTSCR	10X

1 Replacement Door Pins


Bend top of pin as shown.




Install pins in gutter door hinges as needed.


2 Replacement Thread-Forming Screws

1.25" long screw for fronts, breakers, and panel mounted accessories.



3/8” long screw for all other connections.






Note: 50-60 lb-in to be used for connections to enclosure or gutter doors. 35-40 lb-in to be used for all other connections.


Refer to applicable instruction sheet if needed.

3 Replacement Electrical Grease




Apply grease to electrical contact surfaces of device as needed.
WARNING: Avoid contamination of contact surfaces.


4 Replacement Circuit Directory Kit (Metal & Plastic)



Directory Card Holder (Metal)
The card holder consists of an adhesive tape at the back allowing it to stick on any surface.



Directory Card Holder (Plastic)
The card holder has a self-adhesive backing which can easily stick to any surface.



Directory Card Holder (Metal)

Circuit Directory Card

Note: The circuit directory card consists of circuit numbering for quickly identifying and referecing each circuit within system.

Disclaimer : These instructions do not cover all details or variations in equipment nor do they provide for every possible contingency that may be met in connection with installation, operation or maintenance. Should further information be desired or should particular problems arise that are not covered sufficiently for the purchaser's purposes, the matter should be referred to the ABB Company.

ABB Inc.
305 Gregson Drive
Cary, NC 27511

abb.com

We reserve the right to make technical changes or modify the contents of this document without prior notice. With regard to purchase orders, the agreed particulars shall prevail. ABB AG does not accept any responsibility whatsoever for potential errors or possible lack of information in this document.

We reserve all rights in this document and in the subject matter and illustrations contained therein. Any reproduction, disclosure to third parties or utilization of its contents – in whole or in parts – is forbidden without prior written consent of ABB AG. Copyright© 2025 ABB
All rights reserved

DOC. N.° 1SQC900015M0201