

WORK ORDER

MASPL							
Name: : WAGO PRIVATE LIMITED, BLOCK-94, NATIONAL HIGHWAY-8, VADSALA-VARNAMA,VADO DARA, GUJARAT-391243 Billing Address: : BLOCK-94, NATIONAL HIGHWAY-8, VADSALA-VARNAMA,VADO DARA, GUJARAT-391243 Shipping Address: : BLOCK-94, NATIONAL HIGHWAY-8, VADSALA-VARNAMA,VADO DARA, GUJARAT-391243		P.O No. : 7500940 Date : 09/11/2021		W.O No. : WO-2122-NOV-245 Date : 09/11/2021			
Sr.No	Item Description	Qty	Module Details / Rate	Discount	GST	Total	

1	ELECTROMAGNETIC FLOWMETER Part No:AMAG-I-25-AC ELECTROMAGNETIC FLOW METER MAKE : AAVAD MODEL: AMAG - I (INTEGRAL) SERVICE : PLS SPECIFY CONDUCTIVITY : ? 10 ?S/CM OUTPUT : 4 ? 20 MA ISOLATED,RS - 485 ,PULSE DISPLAY : LCD 16X4 LINE 9 DIGIT TOTALIZED FLOW ACCURACY : + / ? 0.5 % OF READING REPEATIBILITY : + / ? 1% PROCESS TEMPERATURE: 0 °C ? 150 °C PROCESS PRESSURE: MAX : 10 KG/CM2 INTERNAL : PTFE LINNING ELECTRODE MOC : SS 316 FLOW TUBE: SS 304 POWER SUPPLY : 230 V AC RESPONSE TIME : 0.3 SEC PROCESS CONNECTION: ASA 150 FLANGED SS 304 OPERATING TEMPERATURE: 55 C ELECTRONICS HOUSING: DIE-CAST ALUMINUM, IP 65 EMPTY PIPE DETECTION: YES BACK LIGHT LCD: YES VELOCITY: 0.2 TO 10 M/S MEASURING UNIT: SELECTABLE KG/H,M3/H,L/H,L/M,L/S,KG/M,KG/S LINE SIZE: 25 MM FLOW RANGE MINIMUM: 0.53 M3/HR FLOW RANGE MAXIMUM: 17.66 M3/HR NABL ACCREDITED CERTIFICATE	2	46,360	40	18	65,646
---	---	---	--------	----	----	--------

2	ELECTROMAGNETIC FLOWMETER Part No:AMAG-R-40-AC ELECTROMAGNETIC FLOWMETER MODEL: AMAG?R (REMOTE) SERVICE : PLS SPECIFY CONDUCTIVITY : ? 10 ?S/CM OUTPUT : 4?20 MA ISOLATED,RS - 485 ,PULSE DISPLAY : LCD 16X4 LINE WITH 15 METER CABLE 9 DIGIT TOTALIZED FLOW ACCURACY : +/- 0.5 % OF READING REPEATIBILITY : +/-1% PROCESS TEMPERATURE: 0 C? 150 °C PROCESS PRESSURE: MAX : 10 KG/CM2 INTERNAL : PTFE LINNING ELECTRODE MOC : SS 316 FLOW TUBE: SS 304 POWER SUPPLY : 230 V AC RESPONSE TIME : 0.3 SEC PROCESS CONNECTION: ASA 150 FLANGED SS 304 OPERATING TEMPERATURE: 55 C ELECTRONICS HOUSING: DIE-CAST ALUMINUM, IP 65 EMPTY PIPE DETECTION: YES BACK LIGHT LCD: YES VELOCITY:0.3 TO 10 M/S MEASURING UNIT: SELECTABLE KG/H,M3/H,L/H,L/M,L/S,KG/M,KG/S LINE SIZE: 40 MM FLOW RANGE MINIMUM: 1.36 M3/HR FLOW RANGE MAXIMUM: 45.21 M3/HR NABL ACCREDITED CERTIFICATE	1	51,560	40	18	36,505
---	---	---	--------	----	----	--------

3	ELECTROMAGNETIC FLOWMETER Part No:AMAG-R-50-AC ELECTROMAGNETIC FLOWMETER MODEL: AMAG?R (REMOTE) SERVICE : PLS SPECIFY CONDUCTIVITY : ? 10 ?S/CM OUTPUT : 4?20 MA ISOLATED,RS - 485 ,PULSE DISPLAY : LCD 16X4 LINE WITH 15 METER CABLE 9 DIGIT TOTALIZED FLOW ACCURACY : +/- 0.5 % OF READING REPEATIBILITY : +/-1% PROCESS TEMPERATURE: 0 C? 150 °C PROCESS PRESSURE: MAX : 10 KG/CM2 INTERNAL : PTFE LINNING ELECTRODE MOC: SS 316 FLOW TUBE: SS 304 POWER SUPPLY: 230 V AC RESPONSE TIME: 0.3 SEC PROCESS CONNECTION: ASA 150 FLANGED SS 304 OPERATING TEMPERATURE: 55 C ELECTRONICS HOUSING: DIE-CAST ALUMINUM, IP 65 EMPTY PIPE DETECTION: YES BACK LIGHT LCD: YES VELOCITY: 0.3 TO 10 M/S MEASURING UNIT: SELECTABLE KG/H,M3/H,L/H,L/M,L/S,KG/M,KG/S LINE SIZE: 50 MM FLOW RANGE MINIMUM: 2.12 M3/HR FLOW RANGE MAXIMUM: 70.65 M3/HR NABL ACCREDITED CERTIFICATE	2	53,570	40	18	75,855
	P & F		0		0	0
	Freight		0		0	0
				Total:	178005.4	
	One Lakh Seventy Eight Thousands Five Rupees Only			Grand Total:	178005.4	
Delivery Time / Date		Delivery by				
		Courier Name		Docket No.		
Prepared by : RAJATSAHANI		Tested by : RAJATSAHANI		Remarks :		

NG

PS

Account

Store

Production