
DRAWING NUMBER:	REV:
70-992	0
ECN NUMBER:	
98-117	



KEY:

- ○ - LED
- ▣ - TEST BUTTON

X101 - JUMPER
X102 - FUSE, 2 amps.
X103 - FUSE, 1.6 amps.
X104 - FUSE, 1.6 amps.
X105 - FUSE, .8 amps.
ALL FUSES ARE RATED FOR 250V

NOTE:
1) IF TAMPER SWITCH IS NOT USED THEN A JUMPER WIRE IS REQUIRED.
2) X101 MUST BE SHORTED FOR PROPER OPERATION! USE P/N FS6202.

TRAFFIC LIGHT WIRE CHART

EXIT	ENTR.	1	2	3	4
FSAFE	FSECURE	GREEN	RED	RED	GREEN
FSECURE	FSAFE	RED	GREEN	GREEN	RED
FSAFE	FSAFE	GREEN	RED	GREEN	RED
FSECURE	FSECURE	RED	GREEN	RED	GREEN

REVISIONS

REV.	DESCRIPTION	BY	DATE
*	**********	***	**/**/**

THESE DRAWINGS & SPECIFICATIONS ARE THE PROPERTY OF AND PROPRIETARY TO PHILIPS INDUSTRIES, INC. AND ARE NOT TO BE DISCLOSED, REPRODUCED, COPIED OR USED AS THE BASIS OF MANUFACTURE OR SALE OF APPARATUS AND/OR DEVICES, OR OTHERWISE WITHOUT PHILIPS' PRIOR WRITTEN CONSENT.

ALL DIMENSIONS ARE IN INCHES UNLESS SPECIFIED

TOLERANCE UNLESS SPECIFIED

0.0 ± 0.060
0.00 ± 0.030
0.000 ± 0.015
0.0000 ± 0.005
ANGULAR ± 0.5°

DESIGNED BY/DATE: GBF 10/26/98

CHECKED BY/DATE: GVB 10/26/98

PHILIPS
ACCESS CONTROL HARDWARE DIVISION
7041 ORCHARD, DEARBORN, MI. 48126

DRAWING TITLE:
MULTI-CONTROLLER CONNECTIONS - ST 32&34 - 110/220VAC

SIZE:	MODEL:	DRAWING NUMBER:	REV:
B	ST 32&34	70-992	0

SCALE: 1 : 2 ASSY: SHEET: 1 OF 1