



TRIBHUVAN UNIVERSITY

INSTITUTE OF ENGINEERING

PULCHOWK CAMPUS

“REINFORCEMENT LEARNING CONTROL SYSTEM FOR A SHELL-AND-TUBE
HEAT EXCHANGER: A DIGITAL TWIN-BASED APPROACH”

BY:

Krishna Dhanuk (079BME020)

Rabin Tamoli (079BME032)

Group “G-07”

A

PROPOSAL SUBMITTED

TO

SAMSUNG INNOVATION CAMPUS (SIC)

SAMSUNG TRAINING PROGRAM

DEPARTMENT OF ELECTRONICS & COMPUTER ENGINEERING

LALITPUR, NEPAL

Date: 2083/02/08

Abstract

This project presents the development of an intelligent heat exchanger control system using Deep Reinforcement Learning (DRL). A Deep Q-Network (DQN) agent is trained within a digital twin environment of a heat exchanger to automatically regulate outlet temperature under varying operating conditions and disturbances. The project integrates principles of thermodynamics, heat transfer, fluid mechanics, control engineering, and artificial intelligence into a unified autonomous control framework. The intelligent controller continuously adjusts the hot fluid mass flow rate to maintain thermal stability while minimizing pressure losses and control effort.

ACKNOWLEDGEMENT

We would like to express our sincere gratitude to everyone who directly and indirectly supported the successful completion of this project titled “REINFORCEMENT LEARNING CONTROL SYSTEM FOR A SHELL-AND-TUBE HEAT EXCHANGER: A DIGITAL TWIN-BASED APPROACH.”

We are especially thankful to our project Supervisor ‘Baburam Dawadi’ and Mentor ‘Janak Kumar Lal’ for their valuable guidance, encouragement, and technical support throughout the development of this work. Their suggestions and feedback greatly helped in improving the quality of the project. We would also like to acknowledge the contribution of SIC Training Program and Team for introducing this workshop and providing us a platform for learning and growing.

Tables of Contents

Abstract.....	2
Acknowledgement.....	3
Tables of contents.....	4
CHAPTER 1: INTRODUCTION.....	5
1.1 Background.....	5
1.2 Objectives.....	5
1.3 Scope of Project.....	5
CHAPTER 2: HEAT EXCHANGER PHYSICS.....	6
2.1 Fundamentals of Heat Transfer.....	6
2.2 Reynolds Number Analysis.....	6
2.3 Nusselt Number Correlation.....	7
2.4 Overall Heat Transfer Coefficient.....	7
2.5 Pressure Drop Modeling.....	8
CHAPTER 3: DIGITAL TWIN MODELING.....	9
3.1 Simulation Environment.....	9
3.2 Disturbance Modeling.....	9
3.3 Digital Twin Concept.....	9
CHAPTER 4: REINFORCEMENT LEARNING FUNDAMENTALS AND DQN..	10
4.1 Introduction to Reinforcement Learning.....	10
4.2 DQN Overview.....	11
CHAPTER 5: METHODOLOGY.....	12
CHAPTER 6: RESULT AND DISCUSSION.....	13,14,15
CHAPTER 7: CONCLUSION.....	15
REFERENCES.....	16

CHAPTER 1: INTRODUCTION

1.1 Background

Heat exchangers are widely used in industries such as power plants, chemical processing, refineries, and HVAC systems for efficient thermal energy transfer. However, maintaining a stable outlet temperature is challenging due to nonlinear thermal behavior, system inertia, and varying operating disturbances. Traditional PID controllers, although widely used, often struggle with changing conditions and require frequent tuning.

This project combines shell-and-tube heat exchanger thermodynamics, Reinforcement Learning, and Digital Twin technology to develop an intelligent autonomous control system. A physics-based digital twin simulates the real heat exchanger, while a DQN reinforcement learning agent learns to control the hot fluid flow rate for optimal temperature regulation. The integration of AI with process control demonstrates a modern and adaptive approach to industrial thermal system automation.

1.2 Objectives

The main objective of this project is to develop an intelligent control system for a shell-and-tube heat exchanger using Reinforcement Learning and Digital Twin technology. The project aims to model the thermal behavior of the heat exchanger and train a DQN reinforcement learning agent to automatically regulate the outlet temperature by adjusting the hot fluid mass flow rate. Another objective is to compare the advantages of intelligent adaptive control over traditional PID-based methods in handling nonlinearities and disturbances.

1.3 Scope of Project

This project focuses on the simulation and intelligent control of a shell-and-tube heat exchanger within a virtual digital twin environment. The scope includes thermodynamic modeling, heat transfer analysis, fluid flow calculations, and reinforcement learning-based temperature control. The project is implemented entirely in Python using neural networks and a DQN reinforcement learning algorithm for autonomous control. The work is limited to simulation-based implementation and does not include direct real-time industrial hardware integration. However, the developed framework provides a strong foundation for future deployment in smart industrial thermal systems and autonomous process control applications.

CHAPTER 2: HEAT EXCHANGER PHYSICS

2.1 Fundamentals of Heat Transfer

Heat transfer is the process of thermal energy moving from a higher temperature region to a lower temperature region. In a heat exchanger, this process occurs between two fluids separated by a solid surface without direct mixing. The efficiency of a heat exchanger depends on how effectively heat is transferred between the hot and cold fluids.

There are three fundamental modes of heat transfer:

1. Conduction: Transfer of heat through a solid material due to temperature difference.
2. Convection: Transfer of heat between a solid surface and a moving fluid.
3. Radiation: Transfer of heat through electromagnetic waves without requiring a medium.

In shell-and-tube heat exchangers, convection and conduction are the dominant mechanisms. The hot fluid transfers heat to the tube wall through convection, heat then passes through the tube wall by conduction, and finally transfers to the cold fluid through convection.

$$Q = m \cdot C_p \cdot \Delta T$$

Where:

- Q = Heat transfer rate
- m = Mass flow rate
- C_p = Specific heat capacity
- ΔT = Temperature difference

This equation forms the foundation for modeling the thermal behavior of the heat exchanger digital twin.

2.2 Reynolds Number Analysis

The Reynolds number is a dimensionless parameter used to determine the nature of fluid flow inside the heat exchanger tubes. It indicates whether the flow is laminar or turbulent, which directly affects heat transfer performance and pressure losses. Higher Reynolds numbers generally improve heat transfer due to increased fluid mixing.

The Reynolds number is calculated using:

$$Re = (\rho * v * D) / \mu$$

Where:

- ρ = Fluid density
- v = Fluid velocity
- D = Pipe diameter
- μ = Dynamic viscosity

In this project, Reynolds number analysis is used to estimate convective heat transfer characteristics and system flow behavior within the digital twin model.

2.3 Nusselt Number Correlation

The Nusselt number represents the ratio of convective heat transfer to conductive heat transfer within the fluid. It is an important parameter for evaluating the effectiveness of heat transfer in the heat exchanger.

For turbulent flow conditions, the Dittus–Boelter correlation is used:

$$Nu = 0.023 * Re^{0.8} * Pr^{0.4}$$

Where:

- Nu = Nusselt number
- Re = Reynolds number
- Pr = Prandtl number

The Nusselt number is then used to calculate the convective heat transfer coefficient, which is essential for determining overall thermal performance.

2.4 Overall Heat Transfer Coefficient

In the NTU–effectiveness method, the overall heat transfer coefficient U is not only used in the basic heat transfer relation $Q = U * A * \Delta T$, but it is also the bridge that connects the physical heat exchanger design to performance prediction through the Number of Transfer Units (NTU). The key idea is that instead of directly relying on temperature differences, the system performance is expressed in a dimensionless form where heat transfer capability is normalized by the heat capacity rate of the fluid. This is done using:

$$NTU = U * A * C_{min}$$

Here, C_{min} is the minimum heat capacity rate of the hot and cold fluids. A higher NTU indicates a more effective heat exchanger because it means a larger heat transfer area or higher overall heat transfer coefficient relative to the fluid's ability to carry heat. In the

NTU–effectiveness framework, U therefore directly governs the effectiveness $\varepsilon=Q/Q_{\max}$, meaning any improvement in convection, reduction in fouling, or enhancement of wall conductivity increases U , which in turn increases NTU and improves overall thermal performance in the digital twin model.

2.5 Pressure Drop Modeling

As fluid flows through the heat exchanger tubes, friction between the fluid and pipe walls causes pressure losses. Excessive pressure drops increase pumping power requirements and reduce system efficiency.

The pressure drop is calculated using the Darcy–Weisbach equation:

$$\Delta P = f \frac{L}{D} \frac{\rho v^2}{2}$$

Where:

- ΔP = Pressure drop
- f = Friction factor
- L = Pipe length
- D = Pipe diameter
- ρ = Fluid density
- v = Fluid velocity

Pressure drop modeling is included in the project to ensure that the reinforcement learning controller not only maintains temperature stability but also avoids excessive flow conditions that increase energy consumption.

CHAPTER 3: Digital Twin Modeling

3.1 Simulation Environment

The simulation environment represents a virtual shell-and-tube heat exchanger system developed entirely in Python. It models the thermal and fluid dynamic behavior of the exchanger under varying operating conditions. The environment continuously updates system variables such as outlet temperature, flow rate, and pressure drop at each simulation step. This virtual setup acts as the training platform for the DQN reinforcement learning agent, allowing safe and repeatable experimentation without affecting physical equipment.

3.2 Disturbance Modeling

In real industrial systems, heat exchangers are frequently affected by disturbances such as fluctuations in inlet temperature, varying flow rates, and changing operating loads. To replicate these realistic conditions, disturbance modeling is incorporated into the digital twin environment. During simulation, sudden changes are introduced to the hot fluid inlet temperature and system conditions. These disturbances test the ability of the DQN controller to maintain stable outlet temperature and adapt to changing thermal behavior.

3.3 Digital Twin Concept

A digital twin is a virtual representation of a physical system that continuously simulates real-world behavior using mathematical and physical models. In this project, the digital twin replicates the operation of a shell-and-tube heat exchanger by modeling heat transfer, flow dynamics, and thermal response. The digital twin provides a safe and cost-effective environment for training the reinforcement learning controller while ensuring that the learned control policy remains physically meaningful and realistic.

Where:

- T_{out} = Current outlet temperature
- T_s = Steady-state temperature
- dt = Simulation time step
- τ = System time constant

This dynamic model enables the digital twin to realistically capture delayed thermal responses and transient system behavior during reinforcement learning training.

CHAPTER 4: REINFORCEMENT LEARNING FUNDAMENTALS

4.1 Introduction to Reinforcement Learning

Reinforcement Learning (RL) is a machine learning approach in which an agent learns optimal control behavior through continuous interaction with an environment. The agent observes the system state, performs an action, receives a reward, and updates its learning policy based on the outcome. Over time, the agent improves its decision-making ability to maximize cumulative reward.

In this project, a Deep Q-Network (DQN) reinforcement learning algorithm is used to control the outlet temperature of a shell-and-tube heat exchanger. The DQN agent interacts with the heat exchanger digital twin and learns how to adjust the hot fluid mass flow rate to maintain stable temperature control under dynamic operating conditions.

RL Components

Component	Description
Agent	DQN controller
Environment	Heat exchanger digital twin
State	Outlet temperature, flow rate, inlet temperature
Action	Increase, decrease, or maintain flow rate
Reward	Temperature tracking performance
Policy	Learned control strategy

The reinforcement learning framework implemented in this project consists of the following components:

The interaction between these components allows the system to autonomously improve its thermal control performance during training.


4.2 DQN Overview

Deep Q-Network (DQN) is a reinforcement learning algorithm that combines Q-learning with deep neural networks to solve complex decision-making problems. Instead of using a traditional Q-table, DQN uses a neural network to estimate Q-values for different actions based on the current state of the environment.

In this project, the DQN algorithm is used to control the outlet temperature of the shell-and-tube heat exchanger. The agent observes system states such as outlet temperature, inlet temperature, and mass flow rate, then selects control actions to regulate the thermal behavior of the system.

The DQN agent learns by interacting continuously with the digital twin environment. At each simulation step, the agent receives a reward based on temperature tracking performance and updates its neural network to improve future decisions. Experience replay and target networks are also used to stabilize training and improve learning efficiency.

The DQN approach enables the controller to learn adaptive and intelligent control strategies capable of handling nonlinear thermal dynamics and operating disturbances more effectively than traditional control methods.



CHAPTER 5: METHODOLOGY

The methodology employed in this project consists of the following key steps:

1. **Heat Exchanger Modeling:** A shell-and-tube heat exchanger model is developed using fundamental heat transfer and fluid flow equations. Parameters such as Reynolds number, Nusselt number, overall heat transfer coefficient, and pressure drop are calculated to simulate realistic thermal behavior.
2. **Digital Twin Development:** A physics-based digital twin environment is created in Python to simulate the real-time operation of the heat exchanger. The digital twin continuously updates outlet temperature and system dynamics under varying operating conditions.
3. **Disturbance Modeling:** Disturbances such as sudden inlet temperature changes and flow-rate variations are introduced into the simulation environment to replicate realistic industrial conditions and evaluate controller robustness.
4. **DQN Reinforcement Learning Implementation:** A Deep Q-Network (DQN) reinforcement learning agent is developed to control the outlet temperature by adjusting the hot fluid mass flow rate. The agent learns through continuous interaction with the digital twin environment.
5. **State, Action, and Reward Design:** The reinforcement learning framework is designed using system states such as outlet temperature, flow rate, and inlet temperature. Discrete control actions and a reward function are defined to encourage stable and efficient temperature control.
6. **Training and Performance Evaluation:** The DQN agent is trained using experience replay and epsilon-greedy exploration techniques. The trained controller is evaluated based on temperature tracking performance, reward progression, disturbance handling, and control stability.

CHAPTER 6: RESULT AND DISCUSSION

6.1 RESULT



Fig: Total Reward vs Episode




Fig: Outlet Temp vs Time Step




Fig: Mass Flow Rate vs Time Step




Fig: Pressure Drop vs Time Step

6.2 DISCUSSION

The results demonstrate the performance of the RL-based heat exchanger control system across training, control, and inlet temperature disturbance. The training progress shows large negative reward spikes in early episodes, indicating unstable exploration, but gradually improves as the agent learns a better policy, although fluctuations suggest incomplete convergence. In the temperature regulation plot, the RL controller successfully drives the system toward the 55°C setpoint and recovers after a noticeable disturbance, showing its ability to adapt to changing conditions. The control action plot reveals that the agent increases and then stabilizes the mass flow rate in a step-like manner, indicating a learned but still coarse control policy. Correspondingly, the pressure drops increases with the mass flow rate, confirming physically consistent behavior in the digital twin. Overall, the RL agent demonstrates effective learning and adaptive temperature control, but the presence of training instability, non-smooth actions, and sensitivity to disturbances highlights the need for further tuning and improved algorithm design for smoother convergence and more optimal control performance.

CHAPTER 7: CONCLUSION

This project successfully demonstrates the development of an intelligent temperature control system for a shell-and-tube heat exchanger using a Digital Twin and Deep Q-Network (DQN) reinforcement learning approach. A physics-based digital twin environment was developed to simulate realistic thermal and fluid flow behavior under varying operating conditions and disturbances.

The DQN agent was trained to regulate the outlet temperature by adjusting the hot fluid mass flow rate. Through continuous interaction with the environment, the agent learned adaptive control strategies capable of maintaining stable temperature control and handling system disturbances effectively.

The project highlights the potential of combining artificial intelligence, reinforcement learning, and digital twin technology for modern industrial process automation. The developed framework provides a strong foundation for future research in intelligent thermal systems, autonomous control, and smart industrial applications.

REFERENCES

Lee, S., Chau, N.-K., & Choi, S. *Deep reinforcement learning-based real-time temperature control in thermoelectric heat exchange system*. Kyungpook National University, South Korea.

Savaş, S. *PID Controller Tuning for Heat Exchanger Systems: A Comparative Study of Classical, Model-Based, Optimization, and Reinforcement Learning Approaches*. Erciyes University, Faculty of Engineering, Department of Mechatronics Engineering, Kayseri, Türkiye.

Saporiti, N., Cannas, V. G., Pozzi, R., & Rossi, T. *Challenges and Countermeasures for Digital Twin Implementation in Manufacturing Plants: A Delphi Study*. Carlo Cattaneo – LIUC University, Castellanza, Italy.