

SYNTHETIC INDUSTRIAL INSPECTION REPORT

Equipment identifier: Boiler Unit B-12

Inspection date: 2026-08-20

Measured pressure: 165 PSI

Measured temperature: 340 F

Observed condition: No visible corrosion or leaks. Pressure reading is above the normal operating range specified in the applicable SOP.

Deviation: recorded pressure exceeds the SOP-allowed maximum.
Immediate review recommended before returning to service.