**Standardised Architectural Modules**

DESIGN COLLABORATIVE
- Architecture
- Planning
- Engineering
- Graphic Design

No.179, III Floor, S.V.Complex, Eswaran koil st., Puducherry-605001

**Checklist: OPD Equipment & Instruments requiring power supply**

Fill in the required details

**Doc. No. 1240-A-Doc-023**

*This checklist lists commonly available in most eye hospitals and hence not a complete list. Please add additional equipment as appropriate*

| S No | Equipment | Size / Footprint | Watts | Ampearage | | Supply | | | Water connection | Others (Mention) |
|---|---|---|---|---|---|---|---|---|---|---|
| | | | | 5A | 15A | General | Stabilised | Uninterrupted | | |
| **I** | **Exam area** | | | | | | | | | |
| 1 | Slit lamp | | | | | O - 1 | | O - 2 | | |
| 2 | Electric torch | | | | | O - 1 | | O - 2 | | |
| 3 | Direct ophthalmoscope | | | | | O - 1 | | O - 2 | | |
| 4 | Indirect ophthalmoscope | | | | | O - 1 | | O - 2 | | |
| 5 | Hand held slit lamp | | | | | O - 1 | | O - 2 | | |
| 6 | CT Scan -viewer | | | | | O - 1 | | O - 2 | | |
| **II** | **Assessment area** | | | | | | | | | |
| 7 | Autorefractometer | | | | | O - 1 | | O - 2 | | |
| 8 | Ophthalmic chart projector | | | | | O - 1 | | O - 2 | | |
| 9 | Ophthalmic chart display | | | | | O - 1 | | O - 2 | | |
| 10 | Refraction table | | | | | O - 1 | | O - 2 | | |
| 11 | Non-contact tonometer | | | | | | | Y | | |
| 12 | Center field exam display board | | | | | | | Y | | |
| 13 | Streak retinoscope | | | | | | | Y | | |
| 14 | Aurochart (or equivalent) | | | | | O- 1 | | Y | | |
| 15 | RAF ruler | | | | | | | ~~Y~~ | | |
| 16 | IOL master | | | | | | | Y | | |
| 17 | Kerotometer | | | | | | | Y | | |
| **III** | **Investigation area** | | | | | | | | | |
| 18 | HFA | | | | | | | Y | | |
| 19 | HRT | | | | | | | Y | | |
| 20 | OCT | | | | | | | Y | | |
| 21 | Fundus camera | | | | | | | Y | | |
| 22 | Specular microscopy | | | | | | | | | |
| 23 | Zywave orbscan | | | | | | | Y | | |
| 24 | Pentacam | | | | | | | | | |
| 25 | Confocal microscopy | | | | | | | | | |
| 26 | B- Scan | | | | | | | | | |
| 27 | USG/UBM | | | | | | | | | |
| 28 | ERG | | | | | | | | | |

| S No | Equipment | Size / Footprint | Watts | Ampearage | | Supply | | | Water connection | Others (Mention) |
|---|---|---|---|---|---|---|---|---|---|---|
| | | | | 5A | 15A | General | Stabilised | Uninterrupted | | |
| **IV** | **Procedure area** | | | | | | | | | |
| 29 | Yag laser | | | | | | | | | |
| 30 | Green laser | | | | | | | | | |
| 31 | Piped oxygen | | | | | | | | | |
| 32 | Cylinder oxygen | | | | | | | | | |
| 33 | Crash cart | | | | | | | | | |
| 34 | Compulsory wheelchair access | | | | | | | | | |
| 35 | Recovery for GA patients | | | | | | | | | |
| **V** | **Required in more than one area** | | | | | | | | | |
| 36 | Wash Basin | | | | | | | | | |
| 37 | Ceiling Fan | | | | | | | | | |
| 38 | Ceiling Light (mention lighting levels) | | | | | 200-300-500 (Range of Service Illuminance) | | | | |
| 39 | Dimmer | | | | | | | | | |
| 40 | Temperature control (Mention type of air conditioning if needed) | | | | | | | | | |
| 41 | Humidity control | | | | | | | | | |
| 42 | Wall mounted TV | | | | | | | | | |
| 43 | Computer - Screen | | | | | | | Y | | |
| 44 | Computer - CPU | | | | | | | Y | | |
| 45 | Printer | | | | | | | Y | | |
| 46 | Data - Internet | | | | | | | Y | | |
| 47 | Data - Telephone | | | | | | | Y | | |
| 48 | **Others (Mention)** | | | | | | | | | |
| 49 | | | | | | | | | | |
| 50 | | | | | | | | | | |
| | | | | | | | | | | |
| | | | | | | | | | | |
| | | | | | | | | | | |