

Standardised Architectural Modules

Version : 1 - Oct-14

Section 5b: Guidelines for OT and Ward

Checklist: Power supply and other requirements for the CSSD equipment (for 4 operating rooms)

The list given below is only indicative; please make changes to (a) size/capacity of the equipment listed here; (b) include additional equipment required; c) power supply requirements;

S No	Equipment	Dimensions	Size / Footprint	Amperage			Supply			Water Connection	Others (please mention)
		L x W		Watts	5A	15A	General	Stabilised	Uninterrupted		
A	Linen washing room										
1	Textile Processing Machine (Washing Machine)	1.2 x 0.9	25 Gauge	3HP			Y			Y	Drainage
2	Hydro Extractor	1.2 x 0.8	25 Gauge	3HP			Y			Y	Drainage
3	Tumble Drier	1.4 x 0.9	25 Gauge	5 HP			Y				Exhaust pipe
B	Linen packing area										
1	Folding Area	2.6 x 0.6					Y				
C	Gas sterilisation area										
1	Ethylene Oxide Sterilizer	1.05 x 0.7	5 CFT	0.5 HP			Y				Exhaust pipe
2	Ethylene Oxide Sterilizer	0.65 x 0.5	2 CFT	0.25HP			Y				Exhaust pipe
D	Sterilization room										
1	Double door autoclave	2.6 x 1.6	24 SR DD HVP	18KW			Y			Y	