

EPICS V4 IOC/DB Requirements from APS

EPICS V4 Plans for SPX Applications

Andrew Johnson

SynApps Experience of V3 Database

- Comments on the V3 database model:
 - Processing model is good
 - Can develop complex processing and control behaviors using general-purpose records
 - Units string is important annotation (3.15 records copy units strings with input links)
 - Put-notify with completion signaled by forward link processing works well
 - Record type gets to decide when a complex operation has completed, not the IOC framework
 - DB design without considering locks, threads (other than lock-sets), or loops
 - Example: User can set energy or wavelength, DB can update the other without looping
 - IOCs are great for creating middle-ware
 - This ability to create layers makes even unintentional collaboration easy
 - Non-blocking requirement for records makes it hard to implement complex operations
 - Record has to keep track of its current state, work out what to do when next called
 - DB equivalents of complex operations (e.g. scalar record) are hard to do
 - Must be able to write record types to do complex operations

Recommendations for V4 Database

- Specific new functionality suggested
 - Analog value type with error bars
 - New Normative Type?
- Data Analysis use-case?
 - Beam-line scientists have never shared much data analysis code in practice
 - For the kinds of analysis some of them do, a V4 IOC database could be sufficient for their first-line data analysis
- Tim is positive about V4, but did make this comment:
 - “I don’t want to re-implement the 15 years of work that went into SynApps using the V4 database”

Additional Ideas

- Subscription parameters (may need a pvAccess extension?)
 - Support the same kinds of things we can do with server-side filtering on 3.15:
 - Client-specific monitor dead-bands, rate limits, conditional monitors etc.
- Reflection API, i.e. be able to ask an IOC what PVs it holds
 - Beamline IOC configurations tend to change frequently
 - We'd like GUIs to be able to adjust automatically to a change, when replacing a detector say
 - A reflection API (RPC?) could be used to populate the ChannelFinder directory and update the Directory Service automatically




SPX Diagnostics DAQ

- Need to collect different types of data from several input sources (EPICS v3 IOCs)
- All data has collection time and rates
- Different types of data are produced at different rates:
 - LLRF Fast Data (IQ Waveforms): ~13.6MB/s
 - LLRF Slow Data (RF Setpoints): ~216KB/s
 - BPM Data: ~1MB/s
- Data has to be processed and correlated for monitoring, diagnostics, and control purposes
- May need to store some of the collected data into files (SPX uses SDDS format) and catalog those in a relational database
- Looking at the Gather service for data collection. May run both V3 and V4 protocols



SPX0 Diagnostic Data Acquisition Option



SPX LLRF MATLAB Simulator

- [illegible]

SPX LLRF MATLAB Simulator

LLRF Simulator Use Case

