EEP3060

Power Engineering Lab

Cable Testing

Professor: Dr. Ravi Yadav

By:

Name	**Roll Number**
Dhyey Findoriya	B22EE024

1 Objective

To measure the insulation resistance of an underground cable using a Megger Insulation Resistance Tester and evaluate whether the insulation is intact and safe.

2 Equipment and Materials

- Megger Insulation Resistance Tester (15 KV)
- Underground cable (the cable to be tested)
- Earth ground (or reference electrode)
- Test leads (usually with crocodile clips or probes)

3 Introduction

The insulation resistance of an underground cable determines the effectiveness of its insulating material in preventing current leakage and ensuring safe operation. A Megger Insulation Resistance Tester applies a high DC voltage across the insulation and measures the resulting leakage current to calculate resistance using Ohm's Law ($R = \frac{V}{I}$). A high resistance value (in megaohms) indicates good insulation, while a low value suggests deterioration, moisture ingress, or potential failure.

Several factors affect insulation resistance, including cable length, temperature, humidity, and aging. Regular testing helps detect early signs of insulation breakdown, preventing electrical hazards and ensuring system reliability.

4 Significance in Power Engineering

1. Ensuring the integrity of cable insulation is crucial for the reliability and safety of electrical systems.
2. Insulation resistance testing helps in identifying potential failures before they lead to breakdowns.
3. Regular testing reduces maintenance costs and prevents hazards like short circuits, electric shocks, and equipment damage.

4. It ensures compliance with industry standards for safe operation.

5. Enhances the longevity of underground cables by detecting insulation deterioration early.

5 Experimental Procedure

1. **Connecting the Megger:**

   - Set the Megger to the appropriate test voltage (typically 500V or 1000V, depending on the cable's voltage rating).
   - Connect the test leads to the conductors of the cable. For a single-phase cable, one lead should be connected to the phase conductor (live) and the other to the ground or earth.
   - Ensure that the earth connection is secure and free from any contamination to avoid erroneous readings.

2. **Testing Process:**

   - Turn on the Megger and initiate the test. The device applies a DC voltage to the cable and measures the insulation resistance between the conductors and the earth.
   - Observe the reading displayed by the Megger once it stabilizes, typically after 60 seconds or more.

3. **Repeat Testing:**

   - Perform the insulation resistance test for each conductor of the cable, especially in the case of multi-core cables.
   - Conduct additional tests to measure the insulation resistance between conductors and the earth ground.

6 Safety Precautions

- Ensure that the cable is fully de-energized before beginning the test to prevent electric shock.

- Wear appropriate personal protective equipment (PPE), such as gloves and safety glasses, while conducting the test.

- Follow the manufacturer's guidelines for using the Megger to prevent instrument damage and ensure accurate readings.
- Avoid contact with live parts and test leads while the Megger is in operation.

7 Observation Table

Phase of Cable	**Insulation Resistance (Giga Ohm)**
Red phase and armor	0.00
Yellow phase and armor	210
Blue phase and armor	210

Table 1: Observation Table for Cable Testing

8 Results and Discussion

- The insulation resistance readings obtained from the Megger provide insight into the condition of the underground cable.
- A high insulation resistance value indicates that the cable insulation is in good condition and free from moisture or degradation.
- A low insulation resistance value suggests possible faults, moisture ingress, or aging of the insulation material.
- During testing, it was observed that the red wire exhibited the minimum insulation resistance, indicating potential insulation degradation or the presence of moisture.

9 Conclusion

The insulation resistance test using the Megger successfully determined the condition of the underground cable. The results indicate that most of the cable insulation is in good condition, except for the red phase, which shows signs of deterioration. Regular testing and maintenance are essential to ensure the reliability and safety of underground cables.