

Specification



Modularity and Redundancy

- **Power Modules:** The system shall be composed of hot-swappable, redundant power modules of either 30kW capacity (as per the specific E-series model).
- **Initial Configuration:** The 60kVA system must be configured with at least N+1 power module redundancy.
- **Control Modules:** Dual, hot-swappable, redundant system control modules.
- **Scalability:** Power capacity shall be increased by adding additional power modules up to the system maximum of 120kVA without requiring a system shutdown or a new central UPS frame.
- **Hot-Swappability:** All modules (power, control, bypass) must be hot-swappable without the need for tools and without interrupting output power to the critical load.

Battery System

- **Type:** Sealed, Lead-Acid,
- **Battery Voltage:** To be specified by the bidder based on the UPS DC link requirements.
- **Backup Time:** A minimum of **15 minutes at full 60kW load**.
- **Battery Cabinet:** Supplied in a standalone, touch-safe cabinet with circuit breakers and monitoring.
- **Future Expansion:** The battery cabinet/system design must allow for the parallel addition of battery packs to support the future 120kVA load without replacing the initial installation.

Display and communication

- **Display:** A large, color LCD touchscreen for intuitive system status, metrics, alarm logging, and configuration.

Done