

INSYS icom

support information				
support date	support start time	support end time	total time periods	REMARK
18-02-2022	14:35	15:20	45 minutes	MRX 3 UPDATE NEW FRIMWARE UPDATE . DEVICE HANG & ITS NOT WORKING.
03-03-2022	13:30	15:00	90 minutes	mrx 5 conect schinder pm5563 meter connect. & explane how to conect modbus devices. Shows holding reseisters of pm5563 meters.
04-03-2022	14:00	18:10	4 hours	trying toavtech sensor conecti insys icom devices
05-03-2022	10:00	18:10	8 hours	connect sussefull sensors to insysicom device
07-03-2022	13:30	14:50	80	container restart & new licence add shows sensors output 192.168.1.26
07-03-2022	15:20	15:50	25	try to connect team viewer iot project
07-03-2022	16:45	18:05	80	mrx 5 conect snider EM1200 using rs485 port getings output but this ports not shows same outputs compare to other rs485 converter device.
08-03-2022	13:25	13:55	30	trying to connect insys device to team viewer iot containeer

|

.