

POWER SYSTEM OPERATION CORPORATION LIMITED

(A Govt. of India Enterprise)

Southern Regional Load Despatch Centre

29, Race Course Cross Road, Bengaluru - 560009. CIN No: U40105DL2009GOI188682

Phone: 080 22254525, 22204325, 22252612, 22351146, Fax No: 080-22259219

Mobile: 9513243111, 9845782373.

Website: www.srldc.org, www.srldc.in, Email: srldccr@posoco.in, srldccroom@gmail.com



Real Time Telemetry Discrepancy Report

Message No: SRLDC/BT/2022/Feb/1

Date: 17-02-2022 12:15 Hrs

From: REMC, SRLDC

To: Station In Charge

1 NPKUNTA_22

Sir/Madam,

It has been observed that following data points are not updating at SRLDC REMC.

This is impacting grid visibility and forecasting of RE generation.

SL.No	TimeStamp	Station Name	IEC Address	SCADA Key	Point Name	Point Type	Quality
1	2022-02-17 12:00:00	NPKUNTA_22	10025	3822025	23_XFMR_P_T1_OL TC	Analog	Bad
2	2022-02-17 12:00:00	NPKUNTA_22	10031	3822031	30_NPK22_30_T1_M W	Analog	Bad
3	2022-02-17 12:00:00	NPKUNTA_22	10032	3822032	30_NPK22_30_T1_M VAR	Analog	Bad
4	2022-02-17 12:00:00	NPKUNTA_22	3022	1822022	2_NPK22_31552_PR T	SOE/Status	Bad
5	2022-02-17 12:00:00	NPKUNTA_22	5038	2822038	3_NPK22_31552	Status	Bad

Please Note that this is in violation of Indian Electricity Grid Code (IEGC) Clause 4.6.4 "Reliable and efficient speech and data communication systems shall be provided to facilitate necessary communication and data exchange, and supervision/control of the grid by the RLDC, under normal and abnormal conditions. All users, STUs and CTU shall provide Systems to telemeter power system parameter such as flow, voltage and status of switches/ transformer taps etc. in line with interface requirements and other guideline made available by RLDC. The associated communication system to facilitate data flow up to appropriate data collection point on CTU's system, shall also be established by the concerned user or STU as specified by CTU in Connection Agreement. All users/STUs in coordination with CTU shall provide the required facilities at their respective ends as specified in the Connection Agreement"

It is here by requested to take immediate action in order to have complete visibility of the station/developer for reliable and secure System Operation.

-----End of the Message-----