

# POWER SYSTEM OPERATION CORPORATION LIMITED

(A Govt. of India Enterprise)

## Southern Regional Load Despatch Centre

29, Race Course Cross Road, Bengaluru - 560009. CIN No: U40105DL2009GOI188682

Phone: 080 22254525, 22204325, 22252612, 22351146, Fax No: 080-22259219

Mobile: 9513243111, 9845782373.

Website: www.srldc.org, www.srldc.in, Email: srldccr@posoco.in, srldccroom@gmail.com



### Real Time Telemetry Discrepancy Report

Message No: SRLDC/BT/2022/Feb/1

Date: 17-02-2022 12:15 Hrs

From: REMC, SRLDC

To: Station In Charge

1 SIMHADRI

Sir/Madam,

It has been observed that following data points are not updating at SRLDC REMC.

This is impacting grid visibility and forecasting of RE generation.

SL.No	TimeStamp	Station Name	IEC Address	SCADA Key	Point Name	Point Type	Quality
-------	-----------	--------------	-------------	-----------	------------	------------	---------

Please Note that this is in violation of Indian Electricity Grid Code (IEGC) Clause 4.6.4 "Reliable and efficient speech and data communication systems shall be provided to facilitate necessary communication and data exchange, and supervision/control of the grid by the RLDC, under normal and abnormal conditions. All users, STUs and CTU shall provide Systems to telemeter power system parameter such as flow, voltage and status of switches/ transformer taps etc. in line with interface requirements and other guideline made available by RLDC. The associated communication system to facilitate data flow up to appropriate data collection point on CTU's system, shall also be established by the concerned user or STU as specified by CTU in Connection Agreement. All users/STUs in coordination with CTU shall provide the required facilities at their respective ends as specified in the Connection Agreement"

It is here by requested to take immediate action in order to have complete visibility of the station/developer for reliable and secure System Operation.

-----End of the Message-----