



PROMACH PTE. LTD.

8 Temasek Boulevard, Level 42, Suntec Tower Three, Singapore-038988
Tel: 6829 2136 | E-mail: enquiry@promachpl.com | Website: www.promachpl.com
Company REG/GST No: 202008249W



PREVENTIVE MAINTENANCE SERVICE REPORT

REPORT NO.	SERVICE DATE	TIME IN / OUT	TECHNICIAN(S)
AHU-2026-0728-0001	28 Jul 2026	09:15 AM / 11:45 AM	Ramesh Kumar, Arjun Prasad

1. CLIENT & SITE INFORMATION	2. EQUIPMENT INFORMATION
Client Name : Tuas Power Generation Pte. Ltd.	Equipment Category : Air Handling Unit
Site Name : Tuas Power Plant (CCP 5)	Equipment Tag No. : AHU-5-01
Building / Area : Control Building	Equipment Description : AHU-CCP 5
Location : Level 2 - Mechanical Room	Brand / Model : TRANE / AHU-1860
Work Order No. : WO/TP/2026/0728	Serial No. : 1860-TR-2019-00123
PO No. : PO/TP/2026/0550	Capacity / Motor : 18,000 CMH Three Phase
Service Type : Quarterly Maintenance	Asset No. : TP-ACMV-AHU-0501



3. MAINTENANCE CHECKLIST											
No.	Checklist Item	Yes	No	N.A.	Remarks	No.	Checklist Item	Yes	No	N.A.	Remarks
1	Filter condition clean and good	'	-	-	Good	6	Motor condition clean and good	'	-	-	Good
2	Cooling coil clean and good	'	-	-	Clean	7	Belt / Coupling condition	'	-	-	Good
3	Drain pan clean and no blockage	'	-	-	No blockag	8	Vibration normal	'	-	-	Normal
4	Condensate drain flow test	'	-	-	Flow OK	9	Electrical connections tight	'	-	-	All tight
5	Fan / Blower clean and balanced	'	-	-	Balanced	10	Overall operation satisfactory	'	-	-	Satisfacto

4. MEASUREMENT READINGS				
Parameter	Actual	Normal Range	Unit	Status
Supply Air Temperature	13.6	12-16	deg C	Norm
Return Air Temperature	24.8	22-26	deg C	Norm
Room Temperature	23.7	22-24	deg C	Norm
Relative Humidity	56.0	40-60	% RH	Norm
Static Pressure (Supply)	120	80-150	Pa	Norm

5. FINDINGS & RECOMMENDATIONS	6. SPARE PARTS USED	7. SERVICE SUMMARY
Findings: - Fan motor current on Blue phase is h - Noted dust accumulation on return fi Recommendations: - Monitor motor current.	Item DescriptionQtyRemarks	Overall Condition: Good Service Completed: Further Action: Next Service Due: 28 Oct 2026

8. SIGNATURES & ACKNOWLEDGEMENT			
Technician Ramesh Kumar 28 Jul 2026 11:45 AM	Supervisor (Optional) Sridhar M. 28 Jul 2026 12:00 PM	Client Representative Mr. Nasir Bin Abdul Majid 28 Jul 2026 12:15 PM	Company Stamp PROMACH PTE. LTD.

