



PROMACH PTE. LTD.

8 Temasek Boulevard Level 42, Suntec Tower Three, Singapore-038988
Tel: 6829 2136, E-mail: enquiry@promachpl.com, Website: www.promachpl.com
Company UEN / GST No: 202008249W



SERVICE REPORT / DELIVERY ORDER

REPORT NO.

3930

CUSTOMER

Tuas Power Generation Pte. Ltd.

ADDRESS / SERVICE LOCATION

60 Tuas South Avenue 9, Singapore 637607

REPORT DATE

17 Jul 2026

SERVICE MONTH

July 2026

STATUS

Completed

SERVICE TYPE

Regular Service

SERVICE SUMMARY

DLP Service No. 6 for DX AHU-15 at the Fan Control Building.

Work performed

- Checked blower bearing and pulley.
- Washed AHU filters and vacuumed the filters.
- Cleaned the drain tray and vacuumed the drain.
- Checked AHU damper operation.
- Checked the outdoor unit and completed the service wash.

DX AHU-15 - AIR HANDLING UNIT

BRAND

Not recorded

MODEL

Not recorded

SERIAL

Not recorded

LOCATION

Fan Control Building

Checklist results

YES

Check blower bearing and pulley

YES

Wash AHU filters and vacuum filters

YES

Clean drain tray and vacuum drain

YES

Check AHU damper operation

YES

Check outdoor unit and complete service wash

Measurements

AHU AVERAGE CURRENT

29.02 A

CU AVERAGE CURRENT

31.30 A

Equipment note: Service completed and acknowledged by the customer.



dun & bradstreet
D-U-N-S NUMBER 659837257
© [2020] Promach Pte. Ltd. All Rights Reserved.



PROMACH PTE. LTD.

8 Temasek Boulevard Level 42, Suntec Tower Three, Singapore-038988
Tel: 6829 2136, E-mail: enquiry@promachpl.com, Website: www.promachpl.com
Company UEN / GST No: 202008249W



SERVICE REPORT / DELIVERY ORDER

REPORT NO.

3930

COMPLETION AND ACKNOWLEDGEMENT

COMPLETED BY

Karthi, Arun, Marimuthu

ACKNOWLEDGED BY

Nasir Bin Abdul Majid

CUSTOMER DESIGNATION

Sr Tech Officer (SS)

SIGNED DATE

23 Jul 2026

Remarks

No additional remarks.

FOLLOW-UP: No follow-up required.



dun & bradstreet
D-U-N-S NUMBER 659837257
© [2020] Promach Pte. Ltd. All Rights Reserved.