

Steady State Contingency Analysis Report

Report generated: August 23, 2024

Contingency: B70H#B71T (Islands created: ?)

Total number of MVar margin criiteria screened: 0

No violations.

Total number of monitored buses: 457

No violations.

Total number of monitored generators: 225

No violations.No violations.

Total number of OOS margin criteria screened: 5

OOS Violations						
OOS Name	Angle_monitor	Angle_remote	Monitor Bus	Other Bus	cktID	OOS mode
G82P	-11.08	-10.84	602057	667085	1	SLNOS
L20D	-29.47	-27.71	657752	667048	1	SLNOS
M602F	-30.98	-22.6	601001	601013	1	SLNOS

violations.

Total number of monitored branches: 555

No violations.

Total number of monitored two winding transformers: 460

No violations.

Total number of monitored three winding transformers: 24

No violations.