

ENDERASS AUCTIONS PLC

Addis Ababa, Ethiopia

EVALUATION REPORT

Independent Evaluation - Perkins 200 kVA Silent Generator

Ref: EVL-C4000002

Issued: 2026-07-10

Inspection Summary

200 kVA sound-attenuated generator, 2,890 hours. 400A breaker panel mounted.

- Condition: Runs well. Some rust on skid frame base.
- Recommended reserve: ETB 1,450,000
- Recommendation: Mid-size genset with good demand.

Methodology

On-site inspection conducted by licensed Enderass evaluation officer. Comparable sales, replacement cost, and income approach considered where applicable. Photos and measurements recorded.

This document is issued for auction purposes only.

Enderass Auctions PLC - Licensed Auctioneer