

ENDERASS AUCTIONS PLC

Addis Ababa, Ethiopia

EVALUATION REPORT

Independent Evaluation - Cummins 500 kVA Diesel Generator

Ref: EVL-C4000002

Issued: 2026-07-10

Inspection Summary

Standby 500 kVA genset, 1,240 hours. ATS included. Acoustic canopy.

- Condition: Load tested March 2025. Batteries replaced 2024.
- Recommended reserve: ETB 2,980,000
- Recommendation: Low hours. ATS adds value.

Methodology

On-site inspection conducted by licensed Enderass evaluation officer. Comparable sales, replacement cost, and income approach considered where applicable. Photos and measurements recorded.

This document is issued for auction purposes only.

Enderass Auctions PLC - Licensed Auctioneer