

ENDERASS AUCTIONS PLC

Addis Ababa, Ethiopia

EVALUATION REPORT

Independent Evaluation - 100 kW Solar Hybrid Inverter System

Ref: EVL-C4000002

Issued: 2026-07-10

Inspection Summary

100 kW PV array, hybrid inverters, 200 kWh lithium battery bank. Installed 2022.

- Condition: Producing 92% of rated output. Batteries at 94% health.
- Recommended reserve: ETB 4,200,000
- Recommendation: Full system including batteries.

Methodology

On-site inspection conducted by licensed Enderass evaluation officer. Comparable sales, replacement cost, and income approach considered where applicable. Photos and measurements recorded.

This document is issued for auction purposes only.

Enderass Auctions PLC - Licensed Auctioneer