

Water Dam Monitoring with Weather Integration

Alexandre Cunha^{}, Artur Oliveria^[1111–2222–3333–4444], Diogo
Fernandes^[2222–3333–4444–5555], Diogo Silva^[2222–3333–4444–5555], Félix
Martins^{}, Gonalo Santos^[2222–3333–4444–5555], and Pedro
Barbeira^[2222–3333–4444–5555]

Department of Informatics Engineering,
Faculty of Engineering, University of Porto, Porto, PT
{up202400086, up202108663, up202108752, up202104794,
up202108837, up202108839, up201303693}@fe.up.pt

Abstract. Hydroelectric dams are crucial infrastructures for water supply and electricity generation but face significant operational risks from extreme weather, including flooding during heavy rainfall and reduced energy production during droughts. Current monitoring methods are often manual or outdated, requiring the development of smart, autonomous, and remote solutions. This work presents a Cyber-Physical System (CPS) and Internet of Things (IoT) framework designed for real-time dam monitoring and control. The proposed architecture is mapped to a 5-layer IoT stack and the 5C CPS functional model, using Arduino Nano ESP32 controllers for perception and a Raspberry Pi gateway running Node-RED, RabbitMQ, and InfluxDB. Data management follows an Atomic Messaging philosophy via the MQTT protocol to ensure high scalability and time-series optimization. To enhance operational intelligence, a Gradient Boosting Machine (GBM) model was integrated to predict daily inflow and outflow trends using historical hydrological data and weather forecasts. We implemented a proof-of-concept prototype that successfully validates decision support logic via a real-time Node-RED dashboard. The results provide a robust and secure foundation for adapting integrated CPS technologies to large-scale hydroelectric environments.

Keywords: Cyber-Physical Systems (CPS) · Internet of Things (IoT) · Hydroelectric Dam Monitoring.

1 Introduction

The management of hydroelectric dams represents a critical engineering challenge, as these infrastructures are vital for both sustainable water supply and electricity generation. This project is motivated by the inherent risks associated with dam operations: the danger of overflow during periods of heavy rainfall, which presents significant flooding and safety risks, and the threat of drought during dry seasons, which leads to reduced energy production. Currently, monitoring methods can often be inefficient or outdated. Consequently, there is a clear need for a smart, autonomous, and remote monitoring system to unify and optimize these industrial processes.

The primary objective of this project is to develop a Cyber-Physical System (CPS) and Internet of Things (IoT) framework for dam monitoring and control. The proposed solution collects real-time data on variables such as water level, flow rates and rainfall intensity, supporting compliance with the legally required safety control and observation measures defined for each dam class and associated damage potential, in accordance with the Portuguese dam safety framework established by Decreto-Lei n.º 21/2018 [5], which regulates the safety of large and small dams throughout the phases of design, construction, first impoundment and operation. While the legislation does not prescribe a universal operating range in terms of reservoir percentage, this work adopts a conservative operational strategy in which the CPS helps to keep the reservoir within project-defined safe limits (for example, between 20% and 90% of storage capacity). This is achieved through a distributed architecture using Arduino Nano ESP32 units for local data acquisition and a Raspberry Pi gateway running a Node-RED server and MQTT broker. Furthermore, the system supports predictive decisions using weather forecasts and historical data processed via Gradient Boosting Machine (GBM) models, all visualized through a remote Node-RED dashboard for manual and automatic gate control.

2 Related Work

This section reviews the state-of-the-art in IoT and CPS applied to hydroelectric dams. We also specifically address architectures that leverage Machine Learning to enhance monitoring and control mechanisms.

Sadanand et al. [6] present a system integrating **Internet of Things (IoT)** sensors and a **Machine Learning (ML)** model for automated control of dam gates. The system architecture is tripartite: (i) an IoT sensor network strategically deployed in water bodies and within the dam infrastructure; (ii) a predictive model founded on the **XGBoost** algorithm; and (iii) a physical actuation module for gate operation. Water level and velocity data are aggregated and processed by a central unit based on **Raspberry Pi**. The XGBoost model is calibrated to classify hydrological risk into three states (*Alert*, *Warning*, and *Danger*), which subsequently and automatically triggers the progressive opening of the gates.

The authors report an accuracy of 60%, a result obtained through the utilization of a synthetic dataset generated via the **Scikit-learn** library. Notwithstanding its architectural robustness and integrated automation, the system lacks empirical validation with real-world data and presents inherent limitations concerning scalability and reliability under adverse environmental conditions.

Aditya et al. [1] propose a hybrid system that merges IoT technology with **Artificial Neural Networks (ANN)** for monitoring and meteorological forecasting. The model incorporates water level, pressure, and temperature sensors linked to **Arduino Uno** microcontrollers and **ESP8266** modules, leveraging the **ThingSpeak** platform for cloud communication. The collected data are employed in predicting weather conditions and estimating water flow behavior, thereby enabling automated gate actuation in scenarios of imminent risk.

The ANN algorithm demonstrated an accuracy of 87% in predicting meteorological events (i.e., heavy rain, fog, and thunderstorms) following training with environmental data. The architecture is complemented by a mobile application that provides real-time notifications to operators and alerts local populations. Key limitations include the requirement for manual intervention in certain operational phases, the reduced experimental scale (testing limited to two dam prototypes), and the omission of a performance assessment of the model within real operational environments.

Siddula et al. [7] represent one of the initial attempts to apply IoT for real-time dam monitoring. The system utilizes water level sensors connected to microcontrollers and employs Wi-Fi-based wireless communication for data transmission to a central control panel and a mobile application. Upon a rapid increase in water level, the system issues alerts and facilitates the remote control of the gates.

Although this solution offers a low-cost and easily maintainable implementation, its nature is predominantly **reactive**—it does not incorporate data-driven predictive models, relying solely on fixed thresholds for risk detection. Consequently, this approach does not anticipate flood events with sufficient lead time for the deployment of effective preventative measures.

The article published in the journal *Sensors* [3] introduces an advanced methodology for river flow forecasting, based on **Deep Neural Networks** of the **Multi-Layer Perceptron (MLP)** type. The study utilizes historical time series data encompassing flow rate, precipitation, and temperature as input for model training, which aims to predict the volume of water flow over short-term temporal horizons.

The results demonstrate that the MLP model surpasses conventional algorithms, such as linear regression and **Support Vector Machines (SVM)**, in terms of predictive accuracy and stability. The principal contribution of this study lies in validating the applicability of **Deep Learning (DL)** to hydrological forecasting, suggesting that such models can serve as a valuable complement to existing IoT systems. Nevertheless, the investigation is confined to theoretical forecasting and does not address its direct integration with physical gate control systems.

Table 1 summarises the main characteristics, reported performance, and limitations of the reviewed systems.

Reference	Core Technology Framework	AI/ML Model Employed	Primary Operational Function	Reported Performance Metric	Critical Limitations and Gaps
Sadanand et al. (2021)	IoT + Raspberry Pi Unit	XGBoost (Machine Learning)	Autonomous Sluice Gate Control	Accuracy of 60% (synthetic dataset)	Absence of empirical validation; scalability and reliability constraints in adverse environments.
Aditya et al. (2021)	IoT + ANN + ThingSpeak Platform	Artificial Neural Networks (ANN)	Environmental Monitoring and Meteorological Forecasting	Accuracy of 87% (meteorological prediction)	Manual intervention required; restricted testing scale; no real-world assessment.
Siddula et al. (2018)	IoT + Wi-Fi Communication	None (fixed threshold logic)	Real-Time Monitoring and Alert Generation	Low-cost implementation and ease of maintenance	Reactive nature; no proactive flood anticipation; static risk thresholds.
<i>Sensors</i> (2025)	Deep Learning Methodology	MLP (Deep Learning)	Fluvial Flow Volume Forecasting	Outperforms linear regression and SVM	Theoretical forecasting only; no direct gate control integration.

Table 1. Comparison of related works.

The analysis of the reviewed literature reveals a clear evolution in the application of artificial intelligence to dam monitoring. Early systems, based exclusively on IoT, such as that by Siddula et al. [7], prioritised real-time data collection and visualisation but lacked predictive capability. With the advancement of Machine Learning and Deep Learning models, hybrid solutions emerged, exemplified by the contributions of Sadanand et al. [6] and Aditya et al. [1], capable of forecasting risks and enacting automated responses. Nevertheless, the majority of the proposed systems continue to face significant challenges: namely, the scarcity of real-world data for model training, the inherent limitation of small-scale prototypes, and the absence of robust integration between the predictive modules and the physical control mechanisms. The 2025 study [3] highlights the substantial potential of Deep Learning in accurately forecasting river flow, yet it fails to address the physical execution of the necessary actions in response to the generated alerts. Thus, a discernible gap persists between advanced computational

models and their practical implementation within distributed and resilient IoT environments.

In conclusion, the analysed contributions demonstrate substantial progress in the utilisation of IoT, Machine Learning, and Deep Learning for automated dam management. The most recent solutions successfully incorporate predictive models and alert mechanisms; however, the technological maturity remains constrained by factors such as the scarcity of real-time data, the complexity inherent in model calibration, and communication limitations among devices operating in remote environments.

Future research in this domain should, therefore, focus on the following directives:

- Achieving seamless integration between advanced predictive models and the physical control systems.
- Acquiring long-term, real-world datasets for the robust training and validation of predictive models.
- Developing distributed architectures based on **Edge Computing** to enable localised data processing and decision-making.
- Enhancing the resilience and cybersecurity of IoT systems applied to the management of critical infrastructure.

These advancements will facilitate the construction of systems that are more intelligent, scalable, and reliable for disaster prevention and the optimisation of water resource management.

3 Proposed Solution

The proposed solution architecture is a multi-layered Cyber-Physical System (CPS) designed for reliability and scalability. It integrates physical sensing, edge computing, and cloud-based data management to create a resilient monitoring loop for hydroelectric dam operations.

3.1 System Design and Architecture

System Architecture and Layers The system is structured according to the 5-layer IoT architecture, ensuring a clear separation between physical acquisition and business logic:

- **Perception Layer (Smart Connection Level):** This layer consists of Arduino Nano ESP32 controllers interfaced with pressure transducers for level monitoring, water flow sensors, and pluviometers.
- **Network Layer:** Communication is established via MQTT over Wi-Fi for the prototype, utilizing a "Topic Strategy" that prioritizes single-input trunks (e.g., `sensors/#`) to ensure all incoming data is captured automatically.
- **Middleware Layer (Cyber Level):** A Raspberry Pi serves as the central gateway, hosting a RabbitMQ message broker for reliable delivery and an InfluxDB time-series database for high-performance storage.
- **Application and Business Layers:** Node-RED provides the core logic engine and Human-Machine Interface (HMI). It processes data, triggers safety alerts if the dam exceeds safe limits (20%–90%), and presents real-time visualizations for manual override capabilities.

CPS 5C Architecture Mapping The system is further analyzed through the lens of the 5C functional architecture for Cyber-Physical Systems, which facilitates a transition from raw physical data to autonomous configuration.

1. **Connection (Data Acquisition):** This initial layer focuses on the seamless acquisition of data from the physical asset. In our system, this involves the integration of pressure transducers, pluviometers, and power output meters, alongside solenoid valve actuators.
2. **Conversion (Data Preprocessing):** Raw data is processed at the edge to become "smart" and structured. Our implementation utilizes Node-RED for data aggregation, where local pluviometer data is combined with external Weather API streams.
3. **Cyber (Data Processing and Analysis):** This layer creates the "Digital Twin" of the dam. Centralized processing is handled by the RabbitMQ message broker, which ensures data persistence and provides a virtual representation of the system state for historical analysis and storage.

4. **Cognition (Awareness and Insight):** This level applies advanced analytics. We employ Gradient Boosting Machine (GBM) models for AI-based inflow/outflow forecasting, which generates high-level awareness of current conditions to support a Decision Support System (DSS).
5. **Configuration (Self-adaptation and Control):** This final level enables the feedback loop. The system translates AI-driven insights into actual commands (e.g., opening a valve by 15%) while maintaining a "Human-in-the-Loop" through the Node-RED dashboard for manual overrides.

Data and Ingestion Strategy The system employs an "Atomic Messaging" philosophy based on a decoupled architecture. Rather than sending complex bundled packets, each physical device acts as separate logical sensors, transmitting independent MQTT messages for each measurement type. This approach ensures the backend remains generic and can scale to new sensor types without structural changes.

Every sensor payload follows a strict JSON "Data Contract" to maintain consistency across the platform:

- **id:** A unique UUID for hardware identification.
- **kind:** The measurement type (e.g., `flow_rate`), which Node-RED maps directly to the InfluxDB measurement name.
- **units:** Saved as metadata (Tags) to differentiate between measurement scales.
- **data:** The raw numerical value used for real-time graphing and historical analysis.
- **time_stamp:** A Unix timestamp used to index data points accurately on the temporal X-axis.

3.2 Database Selection and Logic

InfluxDB was selected as the primary data store due to its native optimization for time-series streams. Unlike relational databases, it provides high-ingest performance for million-point streams and automated lifecycle management through Retention Policies (e.g., `KEEP 30 DAYS`), preventing storage exhaustion. Data ingestion is handled directly within Node-RED to allow for logic-first preprocessing, enabling the system to filter bad readings or outliers before they reach the database.

3.3 Implementation Details

The development of the prototype was executed through a hardware-software integration process, prioritizing modularity and real-time responsiveness. Figure 1 presents the general architecture of the proof-of-concept solution, including the data pipeline, from sensor information to ML predictions. The complete implementation details are categorized as follows.




Fig. 1. Architecture of the prototype implemented. In comparison to the original architecture proposed for the application, we include simulated sensors and there is no actuation pipeline.

Hardware Setup and Data Acquisition The physical layer utilizes an Arduino Nano ESP32 units for local data acquisition. These controllers interface with a diverse sensor suite, including water flow sensors for monitoring inflow and outflow rates, rain gauges (pluviometers) for rainfall intensity, and pressure sensors that determine water levels via hydrostatic pressure. Additionally, power monitoring sensors track turbine voltage and current to calculate energy output. For the prototype, sensor data is simulated and scaled to mirror real-world hydrological conditions.

Communication Infrastructure Data transmission is built on a decoupled “Atomic Messaging” philosophy. Each sensor measurement (e.g., temperature, distance, flow) is sent as an independent MQTT message to its own specific topic (e.g., `sensors/temperature/ws_01`). While the final deployment is designed to scale to LoRaWAN due to its high range, the current prototype utilizes MQTT over Wi-Fi for efficient data transfer to the Raspberry Pi gateway.

Middleware and Backend Logic The Raspberry Pi serves as the central processing hub, running a Dockerized stack consisting of RabbitMQ, InfluxDB, and Node-RED.

- **Message Broker:** RabbitMQ handles the routing of MQTT messages, ensuring reliable and secure delivery through TLS encryption.

- **Data Storage:** InfluxDB was implemented for time-series storage, utilizing "Retention Policies" to automatically manage data lifecycles and prevent storage saturation.
- **Flow Engine:** Node-RED is the primary logic coordinator, responsible for filtering sensor readings and transforming JSON payloads into database-ready formats.

Predictive Analytics Implementation To support proactive dam management, a Gradient Boosting Machine (GBM) model was developed in Python. The model was trained using historical hydrological data from the *Sistema Nacional de Informação de Recursos Hídricos* (SNIRH) [2] and integrated with the OpenWeather API [4]. The system engineers features based on recent flow values and weather data to predict daily inflow/outflow trends.

Human-Machine Interface (HMI) The system provides a comprehensive dashboard built in Node-RED for real-time visualization of all monitored variables. This interface includes automated alerts for overflow or drought conditions and provides manual override buttons for solenoid valve control, ensuring a "Human-in-the-Loop" safety mechanism.

3.4 Implementation Constraints and Design Deviations

During the transition from the theoretical system design to the physical prototype, several constraints necessitated deviations from the original proposed solution. These changes highlight the challenges of hardware availability and the adaptation required for small-scale modeling.

Water Level Sensing: Pressure vs. Ultrasonic Distance The initial design proposed a hydrostatic pressure transducer to measure water levels. However, for the current prototype implementation, an ultrasonic distance sensor was utilized as a primary alternative. While a pressure sensor measures the weight of the water column from the bottom, the ultrasonic sensor measures the distance from the top of the reservoir to the water surface. This shift required a modification in planing for the reservoir model. The ultrasonic sensor, is cost-effective and easier to implement in a small-scale setup but extremely complicated to apply to a real world scenario.

Flow Control: Manual vs. Automated Actuation The proposed architecture included a solenoid valve as an automated actuator to regulate water flow based on AI-driven commands from the Cognition layer. Due to hardware procurement limitations, the physical actuation is currently performed manually. To maintain the integrity of the Cyber-Physical loop, the system still generates "control recommendations" via the Node-RED dashboard. The operator acts as the physical link in the feedback loop, executing manual gate adjustments in response to the system's predictive alerts for overflow or drought.

3.5 Benefits and Limitations

We expect that the prototype successfully demonstrates the feasibility of a unified IoT monitoring stack, yet the implementation deviations provide valuable insights into system robustness.

The use of an ultrasonic sensor can be a good alternative for small-scale testing on a controlled environment, though it remains sensitive to surface turbulence and even more susceptible to noise from particles in the air compared to hydrostatic methods. Furthermore, while the current manual control of the dam gate is a limitation of the physical prototype, it can validate other aspects of prototype such as the automated and manual decision control and configuration. This ensures that even without direct electronic actuation, the decision support system provides actionable intelligence that enhances operational safety. Future iterations can focus on re-integrating solenoid actuators to achieve the full "Self-Adaptation" envisioned in the 5C CPS architecture.

4 Evaluation and Results

4.1 Testing Methodology

4.2 Case Studies

4.3 Result Analysis

5 Discussion

5.1 Benefits

5.2 Limitations

6 Conclusion and Future Work

6.1 Future Work

Building upon the current prototype, several directions for future research and development have been identified to transition this system toward a real-world deployment:

- **Sensor Fusion and Precision:** Future iterations will involve testing a wider array of sensors to increase the precision of the Decision Support System (DSS). Integrating additional environmental variables will provide the AI models with a more comprehensive dataset, leading to more accurate automated and manual control recommendations.
- **Actuator Integration for Full Automation:** A primary goal is the addition of a physical solenoid valve or similar actuator to replace the current manual intervention. This will enable the system to close the feedback loop entirely, achieving the "Self-Adaptation" level of the 5C architecture where the CPS can autonomously adjust gate positions based on real-time and predictive data.
- **Comparative Level-Sensing Analysis:** We plan to conduct comparative experiments between ultrasonic distance sensors and hydrostatic pressure sensors. By evaluating the performance of each individually and testing a hybrid configuration (using both sensors simultaneously), we aim to determine which solution provides the highest reliability under varying conditions, such as surface turbulence or debris interference.
- **Real-Dam Adaptation:** The final stage of development involves scaling the communication infrastructure from Wi-Fi to LoRaWAN to meet the range requirements of a real dam site. This phase will also include adapting the software logic to handle the massive data throughput and environmental complexities inherent in large-scale hydroelectric operations.

Acknowledgments. A bold run-in heading in small font size at the end of the paper is used for general acknowledgments, for example: This study was funded by X (grant number Y).

Disclosure of Interests. It is now necessary to declare any competing interests or to specifically state that the authors have no competing interests. Please place the statement with a bold run-in heading in small font size beneath the (optional) acknowledgments¹, for example: The authors have no competing interests to declare that are relevant to the content of this article. Or: Author A has received research grants from Company W. Author B has received a speaker honorarium from Company X and owns stock in Company Y. Author C is a member of committee Z.

¹ If EquinOCS, our proceedings submission system, is used, then the disclaimer can be provided directly in the system.

References

1. Aditya, V., Tanishq, C.T., Sai, V.C.B., Dhuli, S.K.: Iot and ann based automatic water level monitoring for dams. In: 2021 13th International Conference on Computational Intelligence and Communication Networks (CICN). pp. 56–60 (2021). <https://doi.org/10.1109/CICN51697.2021.9574685>
2. Agência Portuguesa do Ambiente: Dados da barragem de albufeira da caniçada: Armazenamento e cotas. <https://snirh.apambiente.pt/> (2025), accessed: 2025-11-25
3. Jesus, G., Mardani, Z., Alves, E., Oliveira, A.: Deep learning-based river flow forecasting with MLPs: Comparative exploratory analysis applied to the Tejo and the Mondego rivers. *Sensors* **25**(7), 2154 (2025). <https://doi.org/10.3390/s25072154>
4. OpenWeather Ltd.: One call api 3.0 (2025), <https://openweathermap.org/api/one-call-3>, accessed: 2025-11-25
5. República Portuguesa: Decreto-Lei n.º 21/2018, de 28 de março – Aprova o regime de segurança de barragens e o Regulamento de Pequenas Barragens. *Diário da República*, 1.ª série, n.º 62, pp. 1368–1394 (2018)
6. Sadanand, V., Pruthi, D., Vanjale, S.B.: Dam monitoring and water control system using machine learning and iot. *International Journal of Creative Research Thoughts* **9**, 2320–2882 (2021), www.ijcrt.orgb188
7. Siddula, S.S., Jain, P., Upadhayay, M.D.: Real time monitoring and controlling of water level in dams using iot. In: 2018 IEEE 8th International Advance Computing Conference (IACC). pp. 14–19 (2018). <https://doi.org/10.1109/IADCC.2018.8692099>